

17. Q. Can we get confirmation where the asbestos-containing materials are?

A. For bidding purposes the bidders shall assume there will not be any asbestos-containing materials encountered. While there are areas within the institutions that may have these materials, they are not anticipated within the scope of work for this contract.

18. Does the owner know if the existing culverts are asbestos-coated?

A. There has been no indication that the culverts are asbestos-coated, culverts for removal under this contract are Corrugated Steel Pipe (CSP).

19. In section 1.15.9 Disposal .3 states payment for disposal of asbestos waste in accordance with measurement procedures in Part 1.6., where is this Part found?

A. As asbestos removal is not anticipated in the scope of work, measurement for payment is not included in the specifications, Section 1.15.9.3 is hereby removed.