



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Sewer System Upgrade,Rehabilitation	
Solicitation No. - N° de l'invitation EZ899-220690/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2021-07-30
GETS Reference No. - N° de référence de SEAG PW-\$PWY-025-9026	
File No. - N° de dossier PWY-1-44051 (025)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-08-12 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Fung, Donna(PWY)	Buyer Id - Id de l'acheteur pwy025
Telephone No. - N° de téléphone (604) 671-9689 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC – William Head Institution – Metchosin, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment 001 is raised to address bidder questions.

Question 1: Is there an anticipated notification of acceptance date (Contract Award) that the sixteen (16) week completion period will commence after providing the substantial completion date?

Response 1: Notification of contract award usually occurs within a week of solicitation close.

Question 2: Can this work be completed in 2022? If so, what is the final Substantial Completion date the work would need to be completed by?

Response 2: Work is to commence immediately after contract award and subject to the Institution's operational requirements. A work schedule from the Contractor is required prior to kick off meeting.

Question 3: Section 33 78 00 Cured in Place Pipe – 2.1, Will the Government of Canada allow Air Inversion Steam Cure instead of strictly UV Cured CIPP?

Response 3: Yes, we will allow air inversion stream cured pipe. However, the Contractor is to supply a specification sheet outlining that their product will be able to meet the minimum specifications detailed in Sections 2.2 and 3.7 in 33 78 00 Cured in Place Pipe Specification for review and approval by the Departmental Representative.

Question 4: If only UV Cured CIPP is allowed, what are the site constraints limiting to only this method of CIPP?

Response 4: See Response 3 above.

Please note that the email address provided in the Invitation to Tender document (English) at **SI02 ENQUIRIES DURING THE SOLICITATION PERIOD**, paragraph 1. contains a typo. The correct email address is: donna.fung@pwgsc-tpsgc.gc.ca.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.