

NOTE:

NOMINAL GAS PIPE SIZE	MAX. SUPPORT SPACING
½" or LESS	2.0m
¾" to 1"	2.5m
1¼" to 2½"	3.0m
3" to 4"	5.0m
5" to 8"	6.0m
10" or LARGER	8.0m

NOTE:
GAS LINE SUPPORT REQUIRED ON BOTH SIDES OF EVERY WELDED OR THREADED CONNECTION & 90° ELBOW

1/A9 TYPICAL GAS LINE / CODUIT SUPPORT DETAIL

N.T.S.



NOTE: MINIMUM SPACING BETWEEN SERVICES TO BE 50mm

2/A9 TYPICAL PIPE ENCLOSURE DETAIL

N.T.S.

Canada

Public Services and Procurement Canada / Services publics et Approvisionnement Canada

Real Property Branch / Direction générale des biens immobiliers

IRC BUILDING SCIENCES GROUP
VANCOUVER • LONDON • MISSISSAUGA • OTTAWA • QUEBEC
TOLL FREE:1-888-407-5245 TEL:613.225.0693
WWW.IRCGROUP.COM FAX:613.225.7331

LEVEL OF CLASSIFICATION:
UNCLASSIFIED

LICENSED PROFESSIONAL ENGINEER
2021-05-17
Z SABHA
100090674
PROVINCE OF ONTARIO

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

revisions	description	date
3		
2		
1	ISSUED FOR TENDER	2021/05/17

A detail no. / no. du detail
B location drawing no. / sur dessin no.
C drawing no. / dessin no.

project / projet

SHIRLEY'S BAY
B91
ROOF REPLACEMENT

3701 CARLING AVE.
OTTAWA, ONTARIO

drawing / dessin

DETAILS
BUILDING B91

Designed By	D.G.F.S.	Conçu par
Date	2021/03/04	(yyyy/mm/dd)
Drawn By	DSP	Dessiné par
Date	2021/03/04	(yyyy/mm/dd)
Reviewed By	D.G.F.S/T.Q.R.S.	Examiné par
Date	2021/03/08	(yyyy/mm/dd)
Approved By	D.G.F.S	Approuvé par
Date	2021/03/08	(yyyy/mm/dd)
Tender		Soumission
Project Manager		Administrateur de projets

Project no. / No. du projet: R.065220.767

Drawing no. / No. du dessin: A9

PWGSC B1 (1000 x 707)

0 10 20mm 40 60 80 100 120 140 160 180 200mm