



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St. / 11, rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Due to the nature of the Request for Proposal,
transmission of bids by mail/courier to PWGSC
BRU will not be accepted.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Fuel & Construction Products Division
L'Esplanade Laurier,
140 O'Connor Street,
East Tower, 4th floor,
Ottawa
Ontario
K1A 0S5

Title - Sujet ELECTRIC CIRCULATION HEATER	
Solicitation No. - N° de l'invitation 23240-210631/B	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 23240-210631	Date 2021-08-09
GETS Reference No. - N° de référence de SEAG PW-\$\$HL-675-80179	
File No. - N° de dossier hl675.23240-210631	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-08-25 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Specified Herein - Précisé dans les présentes Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input checked="" type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Arboleda, Ian	Buyer Id - Id de l'acheteur hl675
Telephone No. - N° de téléphone (343) 543-4040 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See herein.	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

QUESTION AND ANSWER – SERIES 2

- Q1. At Annex A, 5.3.14, please confirm if fuses are acceptable current limiting devices? If not, what is the expectation?
- A1. Refer to amendment below.
- Q2. At Annex A, 5.3.14, please clarify what the requirement for a soft start. Upon initial start-up the heater will be 100% on modulated via full SCR while soft start is usually associated with motors.
- A2. Refer to amendment below.

THIS AMENDMENT IS RAISED TO CHANGE THE REQUIREMENT AND THE SOLICITATION CLOSING DATE. THE FOLLOWING REVISIONS ARE:

1. At the Request for Proposal cover page, solicitation closing box, DELETE in its entirety and REPLACE with the following,

<p>“Solicitation Closes – L’invitation prend fin</p> <p>At – à 2:00 PM</p> <p>On – le 25 August / août 2021”</p>
--

2. At Annex “A” - Requirement, 5.3 Electrical Requirements, 5.3.14, ADD the following,
“Notes: 1. Fuses are acceptable current limiting devices. 2. Modulation via SCR is acceptable.”

ALL OTHER TERMS AND CONDITIONS OF THE REQUEST FOR PROPOSAL REMAIN UNCHANGED.