



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Generator Power System Upgrade	
Solicitation No. - N° de l'invitation EZ899-220509/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2021-08-11
GETS Reference No. - N° de référence de SEAG PW-\$PWY-038-9029	
File No. - N° de dossier PWY-1-44057 (038)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-08-19 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Chiasson (PWY), Danielle	Buyer Id - Id de l'acheteur pwy038
Telephone No. - N° de téléphone (604) 349-7097 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: RCMP – Tofino, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-220509/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy038

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-0-43189

CCC No./N° CCC - FMS No/ N° VME

Amendment 001

Amendment 001 is raised to:

- 1) Incorporate Addendum #1. Please see Addendum #1 attached. The addendum will form part of the Contract documents.

All other terms and conditions to remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

.1 Responses (R) to Questions (Q) Received:

Q.1 Is it possible to know the make and model of the current generator? As the possible electrical contractor for this project, I see that it will not be replaced, but it will need to work with the load shedding contactor controller. Please advise.

R.1 *The generator is Kohler. However, no interconnection between the load shedding contactor controller and the generator is required and none is shown either in detail 1/E3.0. The controller has a very simple circuitry. The contactor automatically de-energizes upon loss of power to the controller and it will energize again once power to the controller is restored and the reset button is pressed.*

Q.2 What is the type/model for the main distribution panel? The photos are not very clear.

R.2 *Eaton CMP-A1*

Q.3 Please advise on the type/model of panel “ENLC”. The photo is blurry for that panel.

R.3 *Eaton Pow-R-Line C PRL1a*

Q.4 I see some temporary work has to take place with panel “E” in which some new breakers will be needed. What is the make and model of panel “E”? Please advise.

R.4 *Eaton Pow-R-Line C PRL1a*

Q.5 Also, what make/model are panels “ENLA”, “ENLB” and “ENLC” as well.

R.5 *Eaton Pow-R-Line C PRL1a*

END OF ADDENDUM No. 1
