



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS Á:
 Parks Canada Agency Bid Receiving Unit
 National Contracting Services

Bid Fax: 1-866-246-6893

Bid Email:
pc.soumissionsami-bidsrpc.pc@canada.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 002 TO A INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:
 Parks Canada Agency
 National Contracting Services
 Calgary, AB

Title: Stephen Creek Bridge Improvements – Yoho National Park	
Solicitation No.: 5P468-21-0104/A	Date: August 19, 2021
Amendment No.: 002	
Client Reference No.: 1488	
GETS Reference No.: PW-21-00965187	

Solicitation Closes: At: 2:00 PM On: August 24, 2021	Time Zone: MDT
---	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Rebecca Chen	
Telephone No.: 587-439-3529	Fax No.: 1-866-246-6893
Email Address: rebecca.chen2@canada.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 002

This amendment is raised to distribute question and answer make changes to the tender package.

A. Questions & Answers

Q1 What is the load rating of the Stephen Creek Bridge?

A1 The load rating for the bridge is CL-525 (as determined by COWI in 2017 and confirmed by Dillon as part of the preliminary engineering report).

Q2 Are design or asbuilt drawings for the bridge available?

A2 See attached provided for information only and with no warranty of accuracy.

Q3 1. Project Manual Section 01 11 00, Part 2 (pg 3 of 3); products in accordance with SSBS unless otherwise specified

1. Section 06 15 00; wood decking and features in accordance with SSBC Section 23, which states

1. Planking – Hemlock/Fir No. 1
2. Handrail posts – Coast Douglas Fir or Hemlock, Select Structural
3. Railings – Pacific Coast Hemlock/Coastal Douglas Fir No. 1

Clarification required as the Tender Drawings state (MATERIALS) states that timber shall be D.Fir-Larch, Hem-Fir, or Spruce-Pine-Fir, Grade No. 2 or better. Are the drawings to be considered “otherwise specified”? Which products are to be used for this contract?

A3 Information specific to the project that is contained on the Drawings or in the Project Manual supersedes the more general requirements of the SSBC. "unless otherwise specified" as used in Project Manual Section 01 11 00, Part 2 means the same as "unless defined otherwise on the Drawings or in the Project Manual".

B. Tender Package

ADD: DSP 3 21-0104

Yho_STC - 1991 01 Site Plan & Layout

Yho_STC - 1991 02 Sections & Details

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED