



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-877-558-2349

Bid E-mail Address: pc.soumissionsami-bidsrpc.pc@canada.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 001 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services

Halifax, Nova Scotia

| | |
|--|--------------------------------|
| Title: Tobey Dock Reconstruction, Georgian Bay Islands National Park | |
| Solicitation No.: 5P468-21-0063/A | Date: 31 August 2021 |
| Amendment No.: 003 | |
| Client Reference No.: 2061 | |
| GETS Reference No.: PW-21-00965317 | |

| | |
|---|------------------------------|
| Solicitation Closes: At: 14:00 On: 07 September 2021 | Time Zone: EDT |
|---|------------------------------|

| | |
|--|-----------------------------------|
| F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/> | |
| Address Enquiries to: Jaime Creaser | |
| Telephone No.: 902-266-8592 | Fax No.: 1-877-558-2349 |
| Email Address: Jaime.Creaser@canada.ca | |
| Destination of Goods, Services, and Construction: See Herein | |

TO BE COMPLETED BY THE BIDDER

| | |
|---|-----------------|
| Vendor/ Firm Name: | |
| Address: | |
| Telephone No.: | Fax No.: |
| Name of person authorized to sign on behalf of the Vendor/ Firm (type or print): | |
| Signature: | Date: |

Solicitation No.:
5P468-21-0063/A

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
2061

Title:
Tobey Dock Reconstruction, Georgian Bay Islands National Park

Amendment 003

This amendment is raised to distribute questions and answers.

1. Questions and Answers

Q11. Please provided a geotechnical report and bathymetry.

A11. There is no Geotechnical Report and water depths to Chart Datum are shown on sheets 0.0, 1.0 and 1.1.

Q12. According with the tender documents, when testing to confirm the length of the SSP, please provide a specification for the test pile.

A12. The test pile is not specified, but should be suited to being driven to the depths required with pile driving equipment.

Q13. Do tie rods, wales and nuts require any extra protection?

A13. No

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED