



<p>RETURN BIDS TO: RETOURNER LES SOUMISSIONS À:</p> <p>Bid Receiving - Environment Canada / Réception des soumissions – Environnement Canada</p> <p>Electronic Copy: ec.soumissions-bids.ec@canada.ca</p> <p>BID SOLICITATION AMENDMENT MODIFICATION DE LA DEMANDE DE SOUMISSIONS</p> <p>The referenced Bid Solicitation is revised in this document; unless otherwise indicated, all other terms and conditions of the Bid Solicitation remain the same.</p> <p>La demande de soumissions citée en référence est modifiée dans ce document; sauf indication contraire, les modalités de la demande de soumissions demeurent les mêmes.</p>	<p>Title – Titre</p> <p>Pacific Wildlife Research Centre Roof Replacement Phase II (Science Wing)</p>	
	<p>EC Bid Solicitation No./SAP PR No. - N° de la demande de soumissions EC / N° SAP PR 5000059402</p>	<p>Amendment No. - N° de modif.</p> <p>003</p>
	<p>Date of Bid Solicitation (YYYY-MM-DD) – Date de la demande de soumissions (AAAA-MM-JJ) 2021-07-21</p>	
	<p>Bid Solicitation Closes (YEAR-MM-DD) - La demande de soumissions prend fin (AAAA-MM-JJ)</p> <p>at – à 18 :00h on – le 2021-09-15</p>	<p>Time Zone – Fuseau horaire</p> <p>EDT</p>
	<p>F.O.B – F.A.B</p>	
	<p>Address Enquiries to - Adresser toutes questions à</p> <p>Shawn Davis shawn.davis@ec.gc.ca</p>	
	<p>Telephone No. – No de téléphone</p> <p>N/A</p>	<p>Fax No. – No de Fax</p>
	<p>Delivery Required (YEAR-MM-DD) – Livraison exigée (AAAA-MM-JJ) 2022-02-28</p>	
	<p>Destination of Services / Destination des services</p> <p>British Columbia</p>	



The bid solicitation is amended as follows

At page 1, Bid Solicitation Closes

Delete: on - le 2021-09-09

Insert: on - le 2021-09-15

QUESTIONS

Q1: Part of our scope of work is to add insulation in the attic cavity. Is this work to be done from the exterior or will we be allowed interior access?

A1: Per the specifications and summary of work, blow-in insulation is specified to be installed from within the attic. There are approximately six (6) attic hatches to access the attic from the interior, this is the preferred method.

Q2: If interior access is allowed, what level of security clearance will be required?

A2: Interior access will be provided by ECCC. Contractors are required to sign/in out on a daily basis while on site, and will be escorted while inside the building. Security Clearance level is not required as contractors will be required to sign/in out daily.


Q3: Can you please provide photos of the interior access as well as photos of the attic space?

A3: See below pages

Q4: I want to confirm that the project schedule is a firm expectation, which is said to be completed in 6 weeks after the award of contract. Also, I want to point out that there is a widespread material shortage and this will be highly improbable. I believe that there has to be some flexibility with completion dates given the current market.

A4: ECCC understands the strains and limitations that COVID-19 has put on the construction industry. ECCC is willing to extend the contract completion date to finish no later than February 28, 2022. ECCC believes this will allow sufficient time to procure the materials necessary and adequately complete the work.

Photos of the hatches







All other terms and conditions of the Bid Solicitation remain the same.