

Wharf Construction
Bay De Verde, NL
P/N: 723237

Page 1
2021-04-14

PART 1 - GENERAL

- | | | |
|-----------------------------|----|--|
| <u>1.1 SECTION INCLUDES</u> | .1 | Materials and installation for Wire and Box Connectors 0-1000 V. |
| <u>1.2 RELATED SECTIONS</u> | .1 | Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section. |

PART 2 - PRODUCTS

- | | |
|----------------------|---|
| <u>2.1 MATERIALS</u> | <p>.1 Pressure type wire connectors: with current carrying parts of copper sized to fit copper conductors as required.</p> <p>.2 Fixture type splicing connectors: with current carrying parts of copper sized to fit copper conductors 10 AWG or less.</p> |
|----------------------|---|

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Remove insulation carefully from ends of conductors and:
1. Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 C22.2 no 65.