



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-877-558-2349

Bid E-mail Address:

pc.soumissionsami-bidsrpc.pc@canada.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is **15 megabytes**. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 004 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

Parks Canada Agency
National Contracting Services
Gatineau, QC

Title: On-Site Sewage Treatment Upgrades, Point Pelee National Park	
Solicitation No.: 5P468-21-0084/A	Date: September 17, 2021
Amendment No.: 004	
Client Reference No.: 807	
GETS Reference No.: PW-21-00965870	

Solicitation Closes: At: 2:00PM On: September 22 , 2021	Time Zone: EDT - HAE
------------------------------------------------------------------------------------	--------------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Christine Piché	
Telephone No.: 873-355-8841	Fax No.: 1-877-558-2349
Email Address: Christine.piche2@canada.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Solicitation No.:
5P468-21-0084/A

Amendment No.:
004

Contracting Authority:
Christine Piché

Client Reference No.:
807

Title:
On-Site Sewage Treatment Upgrades, Point Pelee National Park

Amendment 004

The following is hereby amended:

- A. Answer questions form bidders;

A. QUESTIONS AND ANSWERS

- Q1.** As a follow-up to Question 9 in addendum#3; May we begin in January 2022 if we guarantee the completion still in April 2022? This start date may be required in order to secure all materials and approvals/locates on time.
- A1.** No. See Addendum No.2, response to Question 2. Also see Specs Section 01 14 10 Part 1.2 Work Schedule.
- Q2.** Can an allowance be included for dewatering by well points? These costs can vary greatly depending on water level/soil condition and time of year. It would be fair for all proponents if this was compensated through an allowance in the contract.
- A2.** Cost for dewatering to be included in the bid. Contractor to be prepared to work in a high water table environment. See Appendix A – Geotechnical Report and individual drawings for groundwater table depths.
- Q3.** Are excavated soils to be hauled away off-site by the contractor? It would be easier and more cost effective if Parks had a disposal area on-site.
- A3.** The excavated soils are to be hauled off-site by the contractor and disposed of appropriately.
- Q4.** Is it required for contractors to have a septic licence for this work? We do not see this requirement in the tender documents.
- A4.** Yes, the contractor shall have a septic license to complete the work.
- Q5.** Are the control panels supplied?
- A5.** Yes, control panels are to be supplied.
- Q6.** Can we run our conduit with others in the same trench?
- A6.** Yes, conduit can be run in the same trench. Min. spacing to be 150mm.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED