

Addendum / Addenda

Project Description / Description de projet SAS – Emergency Eye Wash Stations and Emergency Showers /SAS - Bassins oculaires et douches d'urgence		
Solicitation No./N° de sollicitation 21-58045	Project No./N° de projet 6038 SAS-01	W.O. No./N° d'ordre de travail
Departmental Representative / représentant ministériel Jazmin McLean		Date September 23, 2021
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

Please find addendum information below

ADDENDUM #2

Project Name: Emergency Shower and Eyewash Station Replacement

Project No.: 113301120

Date: September 23, 2021

Page 1

ALL BIDDERS SHALL READ THE ENTIRE ADDENDUM AND TAKE INTO ACCOUNT ITEMS AFFECTING THEIR RESPECTIVE RESPONSIBILITIES.

This Addendum forms part of Bid documents issued for above project and no consideration will be entertained for extras to contract due to failure of any bidder to become thoroughly familiar with the Addendum.

Reference to Specifications also applies to drawings with or without specific reference thereto and vice versa. This Addendum consists of **one (1) PAGE(S)**.

GENERAL

1. Can we use PROGRESS fittings on the copper type L water lines?
 - a. No.

APPROVED EQUALS

<u>Fixture</u>	<u>Specified Manufacturer</u>	<u>Equal</u>
EW-2	Haws	Guardian
EW-5	Haws	Guardian
EW-6	Haws	Guardian
EW-7	Haws	Guardian
ES-1	Haws	Guardian
ES-3	Haws	Guardian
EMV-1	Bradley	Guardian/Lawler

Note equals are approved for manufacturer only. The specified product has detailed notes on the product requirements such as lengths and product type that shall be included with the product supplied and any site conditions that required modifications to existing or new infrastructure shall be the responsibility of the contractor upon approval.

END OF ADDENDUM