



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet CCG Base Buoy Maintenance Bldg HVAC	
Solicitation No. - N° de l'invitation F521A-210346/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F521A-210346	Date 2021-10-07
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-9046	
File No. - N° de dossier PWY-1-44070 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-10-14 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – CCG Base Buoy Maintenance Bldg – Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
F521A-210346/A

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No/ N° VME

This Amendment #005 is raised to Issue an Addendum.

Please find Addendum #03 attached.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

Addendum No.3

Date: October 6, 2021

Description: F521A-210346/A CCG Base Buoy Maintenance Building HVAC

General Inquiries/Clarifications:

Question No 1: Section 23 81 40, 2.3.1.4 states “Each outdoor unit serves 1 to 2 indoor units. Indoor units shall be capable of simultaneous heating and cooling from different units. Multi-speed fans shall reduce air flow when loads are reduced to minimize noise and energy use.” Note that the specified equipment is not capable of providing simultaneous heating and cooling for indoor units connected to a common outdoor unit. We recommend separate indoor/outdoor units be specified for each of the 3 zones if this requirement for independent heating and cooling is accurate. Please advise.

Answer: Split heat pump systems shall be as per equipment schedules. Simultaneous heating and cooling for indoor units connected to a common outdoor unit will not be required. Both indoor units (FC-1a and FC-1b) connected to HP-100 shall be in the same operation (heating or cooling). Each indoor unit shall be controlled independently with their dedicated thermostat as shown on drawings

Question No 2: Question and answer #1 in Addendum No.2 discuss the use of the existing panel manufacturer to be used as the source of the new panels being installed. Unfortunately, according to the electrical suppliers, Federal Pioneer no longer manufactures panels and has not for 10 years. Is it possible to change panel manufacturer and provide a panel that is equivalent to what is specified?

Answer: Federal Pioneer’s business and equipment support was taken over by Schneider Electric and therefore is considered to be the same manufacturer.

End of Addendum No.3