



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> New Electrical Independent Power So 3300 Chatham, Steveston - Richmond, BC	
<b>Solicitation No. - N° de l'invitation</b> F1571-210727/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> F1571-210727	<b>Date</b> 2021-10-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-025-9050	
<b>File No. - N° de dossier</b> PWY-1-44098 (025)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Daylight Saving Time PDT <b>on - le 2021-10-14</b> Heure Avancée du Pacifique HAP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Fung, Donna(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy025
<b>Telephone No. - N° de téléphone</b> (604) 671-9689 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO – Steveston Gulf 3300 Chatham – Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation. - N° de l'off. à comm.  
F1571-210727/A

Amd. No. - N° de la modif.  
004

Buyer ID - Id de l'acheteur  
pwy025

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No/ N° VME

---

This Amendment 004 is raised to issue an Addendum.

Please find Addendum 01 attached.

The Addendum will form part of the contract documents.

**All other terms and conditions remain unchanged.**

The following changes in the tender documents are effective immediately. This Addendum will form part of the contract documents.

### **Questions and Answers**

**Q1. Building 61 requires a 600a panelboard, however I can find no panelboard layout etc. can we please request clarification on the breaker requirements? it may be they are expecting to simply remove and replace the existing panelboard, however with a 22ka rating requirement and > 225a main bus that will be a switchboard which is not an off the shelf product.**

A1. Provision of the new 600A, 600V, 3Phase Panel Board by others. Contractor to provide new feeders to the building 61 as per the SLD.

**Q2. The 600A panel provision requirement detailed in this note does not provide a size/count for the breakers required. The panel cannot be accurately priced without this information. Please advise.**

Q2. Provision of the new 600A, 600V, 3Phase Panel Board by others. Contractor to provide new feeders to the building 61 as per the SLD.

**Q3. The drawings/plans attached for 10452 Chatham, Steveston project - Solicitation No. F1571-210727/A, are security protected with "Commenting – not allowed". This setting will not allow us to scale off of the drawings on our software. Are you able to send out a drawing set that allows for commenting?**

Q3. It's 3300 Chatham. We are unable to send out a drawing set that allows for commenting at this point in time.

----End of Addendum----