



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scotia

B3J 1T3

Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions

1713 Bedford Row

Halifax, N.S./Halifax, (N.E.)

Halifax

Nova Scot

B3J 1T3

Title - Sujet Pt Bickerton SAR Emerg Power ADDIT Port Bickerton SAR Ajout d'alimentation électrique d'urgence	
Solicitation No. - N° de l'invitation EB144-221026/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client EB144-22-1026	Date 2021-10-15
GETS Reference No. - N° de référence de SEAG PW-SPWA-110-6183	
File No. - N° de dossier PWA-1-86032 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Atlantic Daylight Saving Time ADT on - le 2021-10-20 Heure Avancée de l'Atlantique HAA	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Miller (PWA) Rachel	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (782) 640-2710 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 005 is raised for the following:

- Refer to the Bid and Acceptance Form.

Delete in it's entirety:

BA06 – CONSTRUCTION TIME (revision 002)

Insert:

BA06 CONSTRUCTION TIME (revision 003)

The Contractor must perform and complete the Work on or before January 31st, 2022 from the date of notification of acceptance of the offer.

- Answer Bidder Questions

1. Section 26 05 43.01 – Installation of Cables in Trenches and in Ducts

Question: Section 3.4 Field Quality Control – Items 3.4.6 and 3.4.7 – Which cabling requires these tests?

Answer: Item 3.4.6 Hipot testing not required.

Item 3.4.7 Leakage current testing not required. Megger test will be sufficient.

2. Section 26 32 13.01 – Power Generation Diesel

It is stated in several locations that we, the electrical contractor are to provide the fuel for testing.

Question: Who is responsible for the initial fill of the generator fuel tank?

Answer: The contractor is responsible for the initial fill of the generator fuel tank; refer to drawing E3 Electrical Note 2 sub-item 5. Attached is the generator shop drawing and docking panel as well for reference.

3. Section 26 36 23 – Automatic Transfer Switch

Item 3.3.2 says the ATS is to be tested by a qualified, factory trained, manufacturer's representative.

Question 1: What manufacturer and model number is the ATS?

Answer 1: ATS is from Cummins, refer to attached equipment shop drawing.

Question 2: If the ATS is Cummins, can the described tests be performed simultaneously with the Generator testing?

Answer 2: PSPC: Yes both test can be performed simultaneously. Ensure the ATS will not be energised before Cummins perform there required tests.

Question 3: If the ATS is Cummins, can the training be performed simultaneously with the Generator training?

Answer 3: Yes.

All other terms and conditions remain the same