




# Bickerton Search And Rescue Station Nova Scotia

## Docking Panel Shop Drawing (R2)

	Public Works and Government Services Canada	Travaux Publics et Services Gouvernementaux Canada
<b>SHOP DRAWING</b>		<b>DESIGN D'ATELIER</b>
Reviewed <input type="checkbox"/> Revu		
Reviewed with Annotation <input checked="" type="checkbox"/> Revu avec Annotation		
Revise and Resubmit <input type="checkbox"/> Reviser et Resoumettre		
By: Name	<u>Hamdi Battikh</u>	Par: Nom
Title	<u>Professional Electrical Engineer</u>	Poste
Signature		Date <u>17 Jan 2018</u>
In accordance with Section 01 33 00 of the Specifications		En conformité avec la section 01 33 00 du devis
Project No.:	<u>R.089636.002 Bickerton SAR</u>	No. du Projet:

### **PSPC:**

- Advice Departmental Representative 5 working days before shipping to site.



Part Number: GDS-031L-LF-I

AMPACITY (A)	AMPACITY CODE IN PART NO.	NO. OF CAMLOKS PER PHASE & NEUTRAL	NO. OF CAMLOKS GROUND	NO. OF TERMINATIONS PER PHASE (600 MCM)
X 300	03	1	1	2

VOLTAGE RATING	VOLTAGE CODE IN PART NO.	STANDARD CAMLOK COLOR
X 240/120V (2H + N + G)	1	GN, WT, BK, RD

OPTION	OPTION DESCRIPTION
1	STAINLESS STEEL

PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF TRYSTAR, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF TRYSTAR, INC. IS PROHIBITED.
MATERIAL
FINISH

UNLESS OTHERWISE SPECIFIED DIM ARE IN INCHES TOL ON ANGLE ± 1° FRACTION ± 1/16 1 PL ± 1/32 2 PL ± .015 3 PL ± .010 INTERPRET DIM AND TOL PER ASME Y14.5M-1994
THIRD ANGLE PROJECTION

APPROVALS	
DRAWN: NDA	DRAWN DATE: 1/16/2018
CHECKED:	CHECKED DATE:
ENG:	DATE:
MFG:	DATE:
QA:	DATE:

TRYSTAR, INC. 2917 INDUSTRIAL DRIVE, FARIBAULT, MN 55021 (507) 333-3990 - (866) TRYSTAR - TRYSTAR.COM			
TITLE: 300A 240/120V OUTPUT DOCKING STATION; LEG KIT; STAINLESS STEEL			
SIZE C	CAGE CODE	DWG. NO. GDS-031L-LF-I	REV -01
SCALE: 1:10	WEIGHT:	SHEET 1 OF 1	