



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Kitsilano CCG SAR Workshop Reconstr Kitsilano CCG SAR Workshop Reconstruction	
Solicitation No. - N° de l'invitation F521A-210639/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F521A-210639	Date 2021-10-26
GETS Reference No. - N° de référence de SEAG PW-SPWY-047-9052	
File No. - N° de dossier PWY-1-44096 (047)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-11-02 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Kyle (PWY), Davis	Buyer Id - Id de l'acheteur pwy047
Telephone No. - N° de téléphone (250) 869-6395 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Kitsilano CCG SAR Workshop – Vancouver, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F521A-210639A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwy047

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

Solicitation Amendment 003 is raised to:

1. Answer bidder questions in Addendum 2.

Kitsilano CCG SAR – Workshop Reconstruction Addendum #2

The following changes / clarifications in the tender documents are effective immediately. This Addendum will form part of the Contract Documents.

Response to Bidders' Inquiries:

Please find below a response to bidder's inquiries received to date.

1. Can the outdoor hangers be galvanized/stainless to avoid painting for corrosion?

Yes.

2. Can we use teck cable from the indoor transformer to Panel PP?

Yes, Teck 90 or ACWU will be acceptable.

3. Can the conductors used from the indoor transformer be Aluminum (AWG 4/0) as opposed to the suggested Copper (AWG 2/0). 2/0 Copper is much more difficult to procure at that size.

Yes, Aluminum is acceptable.

4. Confirming that all indoor wiring will be EMT with BX drops for lights.

Yes.

5. Need more information for fire main heat tracing. Location, Length, Voltage, Supply Location, etc.

See tender drawings and Part 4 of Section 21 01 00 Mechanical specifications.

6. Does this main Breaker require an Electronic Breaker with LSIG?

No. Moulded cased Circuit Breaker is acceptable.

7. Could you provide the current Data tie in location and the current contractor responsible for servicing, repair and upgrading for pricing.

Please see below, the data tie in is located at the red box in the main station building.



- Yes. 15A-2P Circuit Breaker

**Kitsilano CCG SAR – Workshop Reconstruction
Addendum #2**

9. I have reviewed the specifications found on Construct Connect (attached) and noticed that only SBS Modified Bitumen options were included in your designs. I would like to request you to include 3M 3015 Primerless Acrylic Self Adhering Air & Vapour Barriers.

Provide bid as per plans and specifications.

Amendments:

Please find attached amendments to the drawings.

1. The response to Inquiry #14 from Addendum #1 should be revised to read as per below,

3M - 3015VP (Vapour-Permeable), is an acceptable alternative for the Air/moisture barrier noted in assemblies W1 & W2 and as specified in spec section 07 28 00 - 2.3 Vapour Permeable Membrane.

END OF ADDENDUM