

New Boat Storage Building – Makkovik, NL F6879-209226/A

AMENDMENT # 1

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

ADDENDUM NO. 1

CLARIFICATION QUESTIONS:

QUESTION 1: Please confirm if and what type of hazardous materials are involved with the trailer to be demolished.

RESPONSE: For the purposes of disposal associated with the existing trailer, the Contractor is to note that lead and mercury based paint is present on the painted building materials. In addition, given the age of the trailer, concealed asbestos may be present in any encountered texture finishes, mechanical insulation, plaster taping compound, mastic material or floor tiles.

SPECIFICATIONS:

In Specification Section 01 10 10 – General Instructions, **ADD** the following clauses to subsection 1.2:

- a) For the purposes of disposal associated with the existing trailer, the Contractor is to note that lead and mercury based paint is present on the painted building materials. In addition, given the age of the trailer, concealed asbestos may be present in any encountered texture finishes, mechanical insulation, plaster taping compound, mastic material or floor tiles.
- b) Contractor will be required to tee off the 50mm diameter municipex water service line running to the trailer (or alternatively connect to the existing main service line), and extend a new section of 50mm diameter waterline to the new boat storage building. Install self draining hose bib on inside of boat storage building complete with 30m length of new 19mm diameter hose.
- c) Paint the wooden underside of the Owner supplied trailer using an exterior low viscosity mould resistant coating (white or clear colour). Skirt the perimeter of the trailer using treated wood framing and wire mesh. Skirting to be complete with two doors (one at either end; each 1 m x 1m in size) to allow access beneath the trailer if required.

BY SUBMISSION OF ITS TENDER, THE TENDERER CONFIRMS THAT IS HAS READ AND UNDERSTANDS THE
REQUIREMENTS EXPRESSED IN ALL ADDENDA AND HAS INCLUDED ALL COSTS OF THESE REQUIREMENTS IN
THE TOTAL TENDER AMOUNT.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
