



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> OCC UPS Replacement Remplacement de l'ASI du CCO	
<b>Solicitation No. - N° de l'invitation</b> EZ899-221415/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2021-11-04
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-028-9071	
<b>File No. - N° de dossier</b> PWY-1-44124 (028)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Standard Time PST <b>on - le 2021-11-18</b> Heure Normale du Pacifique HNP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lam (PWY), Tian	<b>Buyer Id - Id de l'acheteur</b> pwy028
<b>Telephone No. - N° de téléphone</b> (604) 363-7968 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> RCMP – Kelowna, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-221415/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

---

The Solicitation Amendment 001 is raised to issue Addendum 001.

Please see Addendum 001 herein.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

## **.1 Specifications**

### **.1 Section 26 33 53 – Static Uninterruptible Power Supply**

#### **.1 Add** the sentences 1.12.2 to 1.12.6 to read:

- “.2** Supplier of the UPS shall have local licenced maintenance personnel within 100km of site to provide regular maintenance and on-call services. Provide proof of such representation as part of shop drawing submittal.
- .3** UPS supplier to include a letter of guarantee response time to site within one business day and include that in shop drawing submittal.
- .4** UPS to be warrantied by the system supplier for a period of 3 years from the date of site acceptance. Warranty to include costs of labour and material for any warranty work during that time.
- .5** Lithium ION battery system to be guaranteed by the system supplier for a period of 10 years from the date of site acceptance. Warranty to include cost of labour and material for any warranty work during that time.
- .6** For UPS and Lithium ION battery system warranties noted in the above, the warranties to start at the date of substantial completion, not product delivery, first power, or any other milestones. Warranty letters to be provided as part of the project close out submittals.”

#### **2. Add** the following sentence 1.13.4:

- “.4** UPS and Lithium ION battery system warranty letters”

## **.2 Responses (R) to Questions (Q) Received:**

**Q.1** Is a bid bond required on a project this small?

**R.1** *Bid security is required, but not necessarily in the form of a bid bond. See G108 Bid security requirements for more details: <https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2710T/23>.*

**Q.2** Please confirm UPS warranty. 1 year?

**R.2** *3 years warranty is required for UPS. See item 1.1.1 of this addendum.*

**Q.3** Please confirm Lithium ION warranty. 3 years?

**R.3** *10 years warranty is required for Lithium ION battery system. See item 1.1.1 of this addendum.*

---

- Q.4** The battery cabinet for the UPS is not shown on the single line. Please show the battery cabinet and the wiring between cabinets for the contractors.
- R.4** *Battery cabinet is part of the UPS system. Wiring between UPS/Battery system is considered part of the UPS and battery vendor scope and is within the UPS vendor's scope of design based on their internal equipment protection and operating characteristics.*
- Q.5** Please confirm the batteries are to be lithium ION as the cabinet on the drawing looks like a traditional VRLA cabinet.
- R.5** *Battery system is to be Lithium ION as clearly stated in at least 3 places in specification section 26 33 53.*
- Q.6** The single line drawing shows 2 x battery strings. Please confirm the number of battery strings required and if the back up time is 20 minutes per string or with both strings combined.
- R.6** *Provide 2 battery strings rated for a combined backup time of 20 minutes.*
- Q.7** Also, the single line diagram shows a maintenance bypass switch with SQRU and Kirk keys. Please confirm if this request is mandatory. The Eaton maintenance bypass is c/w electrical interlocking, as a standard, would this be acceptable?
- Q.7** *Provide an external wrap around maintenance bypass complete with electronically interlocked solenoid captive key release system.*

**END OF ADDENDUM No. 1**

---