



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> OCC UPS Replacement Remplacement de l'ASI du CCO	
<b>Solicitation No. - N° de l'invitation</b> EZ899-221415/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2021-11-12
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-028-9071	
<b>File No. - N° de dossier</b> PWY-1-44124 (028)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Standard Time PST <b>on - le 2021-11-18</b> Heure Normale du Pacifique HNP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lam (PWY), Tian	<b>Buyer Id - Id de l'acheteur</b> pwy028
<b>Telephone No. - N° de téléphone</b> (604) 363-7968 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> RCMP – Kelowna, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-221415/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

---

The Solicitation Amendment 002 is raised to issue Addendum 002.

Please see Addendum 002 herein.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

**.1 Responses (R) to Questions (Q) Received:**

**Q.1** The system capacity requested on day one is 30 KVA/30 KW , will you require an additional module for N+1 redundancy delivered on day one too or only the capability/space of having an extra module added when you required it in future?

**R.1** *The required system on day on is to be 30kVA/30kW with one additional module for N+1 redundancy.*

**Q.2** There is a new battery technology that is much safer than Li-Ion yet offers many of the advantage that the Li-Ion batteries have. NiZn batteries have 10 year standard OEM warranty and are completely safe and certified to UL9540A - Test Method Testing the fire safety hazards associated with propagating thermal runaway within battery systems. Are you open to consider this option as an alternative to Li-Ion?

**R.2** *All bids are to be based on Li-Ion battery system as per the Specifications.*

**Q.3** After review of the actual size of the new UPS components. There will not be enough room in the existing UPS #1 location. We will need to relocate the new UPS to the end wall as shown on the attached drawing.

Will there be any issue with using this space?

**R.3** *The space currently occupied by the existing UPS #1 and the entire length of the end wall of the UPS room are available for the installation of new UPS system equipment. See below for the picture of the UPS room end wall. Exact location of UPS system equipment to be coordinated with Departmental representative prior to installation.*



UPS room end wall

---

**Q-4** Can [we] get the list of registered bidders so we collaborate with them offering them for the scope of supply, testing and commissioning of UPS system whilst they focus on the contractual and electrical works of their area of competence.

**R.4** There is no list of bidders that will be published.  
However, on the buyandsell.gc.ca website there is a 'voluntary' List of Interested Suppliers that you can view or elect to register. Visit [www.buyandsell.gc.ca](http://www.buyandsell.gc.ca) and view "Access the List of Interested Suppliers for this tender" usually found around the top of the Tender Notice – Notice of Proposed Procurement page.

**END OF ADDENDUM No. 2**

---