



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Comm towers and supporting infrastr Tours de communication et l'infrastructure de soutien	
<b>Solicitation No. - N° de l'invitation</b> F1705-210916/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> F1705-210916	<b>Date</b> 2021-11-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-9058	
<b>File No. - N° de dossier</b> PWY-1-44105 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Standard Time PST <b>on - le 2021-11-23</b> Heure Normale du Pacifique HNP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO – Denny Island & Safety Mountain – Bella Bella & Calvert Island, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Amendment 006 is raised to address a question.

**Q1.** The cost of flying a concrete tester to site for every concrete pour adds a very significant amount of cost to this project. Will CCG accept cylinders cast by the contractor and brought back to the tester for each pour? This will drastically reduce costs.

The cylinders would be brought back at the end of each crew shift to further reduce costs. Please also reconsider the testing specifications also for slump, air, etc.

**A1.** *CCG will accept concrete cylinders cast by the Contractor provided that any person who will be doing the cylinders is certified as an ACI (American Concrete Institute) Concrete Field Testing Technician – Grade I. Proof of certification is to be provided in the Construction Plan. Timing for transportation of cylinders from site to the lab will be discussed in the contract phase. The other specified concrete field tests and documentation can also be done by this same person in lieu of an independent agency.*

*Lab tests are to be completed by an independent third party as specified.*

All other terms and conditions remain unchanged.