





NOTES:

1. ALL PLUMBING TO BE IN ACCORDANCE WITH THE LATEST EDITION OF THE CANADIAN PLUMBING CODE AND LOCAL AUTHORITIES.
2. CO-ORDINATE WORK WITH WORK OF OTHER TRADES.
3. ARCHITECTURAL DRAWINGS SHALL GOVERN PLUMBING FIXTURE LOCATIONS.
4. SLOPE SANITARY PIPING 3 NPS AND UNDER AT 1:50 ALL OTHER SANITARY PIPING TO BE SLOPED AT 1:100.
5. ALL FLOOR DRAINS (EXCEPT FLOOR DRAINS IN THE GEAR ROOM/MECH. ROOM) TRAP PRIMED FROM THE NEAREST LAV OR SINK.
6. MINIMUM SANITARY BELOW GRADE TO BE 2 NPS.
7. PROVIDE FIRE STOPS FOR ALL PIPING THRU FIRE RATED WALLS/FLOORS.
8. PROVIDE CLEANOUTS AT THE BASE OF ALL SANITARY RISERS.
9. PROVIDE ACCESS DOORS FOR ALL WALL TYPE CLEANOUTS.
10. PROVIDE ACCESS PANELS FOR ALL VALVES LOCATED ABOVE DRYWALL CEILINGS.
11. INSULATED (AS PER SPECIFICATION) ALL DCW, DHW AND RECIRCULATION PIPING.
12. ALL PIPE SIZING IN NPS.
13. PLUMBING CONTRACTOR AND SITE SERVICES CONTRACTOR TO COORDINATE EXACT SUPPLY WATER AND DRAINAGE LINE ENTRANCE LOCATIONS.
14. ALL ABOVE GROUND VENT AND DRAINAGE PIPING ON FIRST AND SECOND LEVELS ARE TO BE COPPER (2NPS AND LESS), OR CAST IRON (GREATER THAN 2 NPS).
15. SEE DRAWING M3 FOR PLUMBING DETAILS.
16. TRAP PRIMER STATION SIMILAR TO PPP PR-500, C/W DU-4 DISTRIBUTION UNIT. INSTALL PER MANUFACTURERS REQUIREMENTS.

LEGEND:

- V --- VENT LINE
- C - CONDENSATE DRAIN LINE
- UNDER SLAB SANITARY
- ABOVE GROUND SANITARY
- DOMESTIC HOT WATER
- DOMESTIC COLD WATER
- DOMESTIC WATER RECIRCULATION
- t.p. - TRAP PRIMER LINE
- BFP BACKFLOW PREVENTER
- M WATER METER
- NFHB NON FREEZE HOSE BIBB
- P-4 PLUMBING FIXTURE TYPE
- FFD FUNNEL FLOOR DRAIN
- FD FLOOR DRAIN
- FE FIRE EXTINGUISHER
- GLOBE VALVE
- SD SHOWER DRAIN



GROUND FLOOR PLAN

SCALE: 1:50
0m 1m 2m 3m 4m 5m

SECOND FLOOR PLAN

SCALE: 1:50
0m 1m 2m 3m 4m 5m

0	ISSUED FOR TENDER	APR 2007
revisions		date
project	CCG STATION SHIPPAGAN POSTE DE LA GCC DE SHIPPAGAN SHIPPAGAN	projct
COMTE DE GLOUCESTER COUNTY, NB		
drawing	FIRST AND SECOND FLOOR PLUMBING PLANS	dessin
designed	P. DYER	conçu
date	2007-03	
drawn	F.A.M.	dessiné
date	2007-03	
approved		approuvé
date		
Tender		Soumission
PWSC Project Manager	Administrateur de projets TPSGC	
project number	303436	no. du projet
drawing no.	M1	no. du dessin