

This amendment is being raised to address the following question(s):

Question(s):

Q1. Can the wooden piles be cut off 300 mm below the mudline?

Q2. Is the end plate shown in the clouded area only at pile cap locations or the entire length of the beam?

Answer(s):

A1. (Corresponds to Q1)

Timber piles to be removed in their entirety as per the drawings and specifications.

A2. (Corresponds to Q2)

End plates are located only at pile cap locations.