

New Boat Storage Building – Makkovik, NL F6879-209226/A

AMENDMENT # 6

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

ADDENDUM NO. 4

CLARIFICATION QUESTIONS:

QUESTION 1: So you are saying there will be all common excavation, no rock will be encountered?
We are very familiar with Makkovik area and anticipate encountering rock during the cut/fill of the site.
Can you confirm that there is no rock.

RESPONSE 1: The response to this question supersedes the response previously provided to Question # 1 in Addendum #3. Contractor is responsible to achieve the new site grades as shown on drawing C2. All below grade concrete foundations are to be installed as shown on the detailed drawings. The Contractor is to note that bedrock may be present on the site at a depth of 600mm below the existing surface. In all instances, the Contractor remains responsible for the work as shown, including rock removal if required.

BY SUBMISSION OF ITS TENDER, THE TENDERER CONFIRMS THAT IS HAS READ AND UNDERSTANDS THE REQUIREMENTS EXPRESSED IN ALL ADDENDA AND HAS INCLUDED ALL COSTS OF THESE REQUIREMENTS IN THE TOTAL TENDER AMOUNT.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
