


DESCRIPTION OF LIGHTING & LIFE SAFETY DEMOLITION:


- 1 TYPICAL (OF 3): DISCONNECT AND REMOVE HARD PIPED LIGHTING FIXTURE TO ALLOW THE CONSTRUCTION OF NEW DUCTWORK. RETAIN CIRCUIT FOR NEW CONSTRUCTION. MODIFY CONDUITS TO SUIT NEW DUCTWORK LAYOUT. COORDINATE WITH MECHANICAL TRADES FOR INTERFERENCES.
- 2 DISCONNECT EXISTING WALL MOUNTED LIGHT. RETAIN FOR REUSE IN NEW CONSTRUCTION.
- 3 DISCONNECT P.A. FIRE SAFETY SPEAKER. RETAIN FOR REUSE IN NEW CONSTRUCTION.
- 4 DISCONNECT FIRE ALARM HORN. RETAIN FOR REUSE IN NEW CONSTRUCTION.
- 5 TYPICAL: DISCONNECT SMOKE DETECTORS. RETAIN FOR REUSE IN NEW WORK.
- 6 DISCONNECT AHU-5 DUCT SMOKE DETECTOR MODULE. RETAIN FOR REUSE IN NEW LOCATION. MODIFY AND EXTEND CONDUIT AS REQUIRED TO REMOVE JUNCTION BOX ABOVE NEW LOCATION OF DUCTWORK. RETAIN MODULE FOR REUSE IN NEW CONSTRUCTION.




1 LEVEL 4 MECHANICAL ROOM M6 PHASE 1 LIGHTING & LIFE SAFETY DEMOLITION
 Scale: 1:100
 E04

DESCRIPTION OF LIGHTING & LIFE SAFETY NEW WORK:

- 1 TYPICAL: PROVIDE LIGHTING FIXTURE C/W CONDUIT AND WIRING. PROVIDE UNISTRUT MOUNTING SUPPORT C/W THREADED ROD ON EITHER END OF DUCTWORK AND MOUNTING ACCESSORIES. MOUNT LIGHTING FIXTURE TO UNISTRUT SUPPORT AND CONNECT TO CIRCUIT RETAINED DURING DEMOLITION. LIGHTS SHALL BE MOUNTED UNDERNEATH NEW DUCTWORK. COORDINATE INTERFERENCES WITH MECHANICAL TRADES.
- 2 INSTALL RELOCATED FIXTURE BELOW NEW DUCT WORK.
- 3 TYPICAL: PROVIDE DUCT SMOKE DETECTORS C/W ADDRESSABLE FIRE ALARM MODULE. PROVIDE CONNECTION TO FIRE ALARM SYSTEM AND VFD DRIVES. MODIFY CONDUIT AND WIRING AS REQUIRED.
- 4 INSTALL RELOCATED PA SPEAKER BELOW LEVEL OF NEW DUCTWORK. MODIFY CONDUIT AND WIRING AS REQUIRED.
- 5 INSTALL RELOCATED FIRE ALARM HORN BELOW LEVEL OF NEW DUCTWORK. MODIFY CONDUIT AND WIRING AS REQUIRED.
- 6 INSTALL RELOCATED SMOKE DETECTOR IN ACCESSIBLE SPACE BETWEEN DUCTWORK AND AIR HANDLING UNIT. COORDINATE WITH MECHANICAL HVAC AND PLUMBING TRADES. MODIFY CONDUIT AND WIRING AS REQUIRED.
- 7 PROVIDE SMOKE DETECTOR MODULE FOR AHU-5. MODIFY CONDUIT AND WIRING AS REQUIRED.
- 8 RETAIN SERVICES OF BASE BUILDING FIRE ALARM CONTRACTOR PROVIDE FIRE ALARM VERIFICATION REPORT.



2 LEVEL 4 MECHANICAL ROOM M6 PHASE 1 LIGHTING & LIFE SAFETY NEW WORK
 Scale: 1:100
 E04



Canada

Publics Works and Government Services Canada / Travaux publics et services gouvernementaux Canada



ProEng CONSULTING INC.
 Building and Energy Engineers
 Unit 105-199 Bayview Dr., Ottawa, ON, Canada, K2J 5W7
 T: 416-762-6244
 www.proengconsulting.com

THESE DRAWINGS, SPECIFICATIONS AND DESIGNS REMAIN THE COPYRIGHTED PROPERTY OF PROENG CONSULTING INC. THESE DOCUMENTS SHALL NOT BE COPIED OR REPRODUCED IN ANY WAY, ON ANY OTHER WORK, WITHOUT THE DIRECT WRITTEN PERMISSION OF PROENG CONSULTING INC.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE PRIOR TO CONSTRUCTION START AND REPORT ALL ERRORS, OMISSIONS AND/OR INTERFERENCES TO THE PROJECT ENGINEER.

THE CONTRACTOR SHALL FOLLOW THE PLAN AND SPECIFICATIONS AS INDICATED. FAILURE TO DO SO WILL VOID ANY LIABILITY OF THE PROJECT ENGINEER.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL MATERIAL RELEVANT TO THE PROJECT. DO NOT SCALE DRAWINGS.

revisions	description	date
04	Issued for Tender	2021.06.17
03	Issued for Tender	2021.09.30
02	Re-Issued for Review	2016.08.04
01	Issued for Review	2016.03.14



project
BAY 3 REFIT PROJECT
 PROJECT ADDRESS

drawing dessin
MECH ROOM M6 LIGHTING & LIFE SAFETY DEMO & NEW WORK PHASE 1

Designed By	Conçu par
Date	M.LACHOWICZ (2021/08/17)
Drawn By	Dessiné par
Date	J.GIBSON (2021/08/17)
Reviewed By	Examiné par
Date	M.LACHOWICZ (2021/08/17)
Approved By	Approuvé par
Date	M.LACHOWICZ (2021/08/17)
Tender	Soumission
Project Manager	Administrateur de projets
Project no.	No. du projet

CSA15-G8b
 Drawing no. No. du dessin
E04