

THESE DRAWINGS, SPECIFICATIONS AND DESIGNS REMAIN THE COPYRIGHTED PROPERTY OF PROENG CONSULTING INC. THESE DOCUMENTS SHALL NOT BE COPIED OR REPRODUCED IN ANY WAY, ON ANY OTHER WORK, WITHOUT THE DIRECT WRITTEN PERMISSION OF PROENG CONSULTING INC.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE PRIOR TO CONSTRUCTION START AND REPORT ALL ERRORS, OMISSIONS AND/OR INTERFERENCES TO THE PROJECT ENGINEER.

THE CONTRACTOR SHALL FOLLOW THE PLAN AND SPECIFICATIONS AS INDICATED. FAILURE TO DO SO WILL VOID ANY LIABILITY OF THE PROJECT ENGINEER.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL MATERIAL RELEVANT TO THE PROJECT. DO NOT SCALE DRAWINGS.



04	Issued for Tender	2021.08.03
03	Issued for Tender	2020.09.30
02	Re-issued for Review	2016.08.04
01	Issued for Review	2016.03.14

revisions	description	date
-----------	-------------	------



project


BAY 3 REFIT PROJECT

PROJECT ADDRESS

drawing dessin

MECHANICAL SECTIONAL COMPOSITE VIEWS


Designed By	J.ALEXANDER	Conçu par	J.ALEXANDER
Date	(2021/08/17)		
Drawn By	R.CAMERON	Dessiné par	R.CAMERON
Date	(2021/08/17)		
Reviewed By	J.ALEXANDER	Examiné par	J.ALEXANDER
Date	(2021/08/17)		
Approved By	J.ALEXANDER	Approuvé par	J.ALEXANDER
Date	(2021/08/17)		
Tender	M. LACHOWICZ	Soumission	M. LACHOWICZ
Project Manager	Administrateur de projets		
Project no.	No. du projet		
	CSA15-G8b		
Drawing no.	No. du dessin		
	M03		



DESCRIPTION OF HVAC DEMOLITION:

- ① REMOVE INDICATED DUCTWORK.
- ② PATCH WALL PENETRATIONS TO MATCH EXISTING WALL CONSTRUCTION & FIRE RATING WHERE ABANDONED.
- ③ NOTE THIS IS A COMPOSITE DRAWING WHICH DOES NOT INCLUDE PROJECT PHASING. REFER TO DRAWINGS M8 & M9 FOR DUCTWORK PHASING.
- ④ PROVIDE PROTECTION AND TARPING. REFER TO SPECIFICATIONS.

1
LEVEL 4 MECHANICAL ROOM M6
HVAC SECTIONAL VIEW - COMPOSITE DEMOLITION
Scale: 1:100



DESCRIPTION OF HVAC NEW WORK:

- ① PROVIDE NEW DUCTWORK.
- ② PROVIDE STRUCTURAL SUPPORT FOR NEW DUCTWORK FROM EXISTING COLUMNS. CONTRACTOR SHALL ALLOW FOR WELDING OF NEW DUCTWORK SUPPORTS FROM EXISTING COLUMNS INCLUDING PRIMING & REPAINTING TO MATCH EXISTING. REFER TO STRUCTURAL ENGINEERING DRAWINGS FOR DETAILS.
- ③ PROVIDE NEW RETURN AIR SILENCERS IN VERTICAL.
- ④ PROVIDE NEW RETURN MANUAL BALANCING DAMPERS.
- ⑤ CONTRACTOR SHALL CUT, PATCH, REPAIR & PAINT DRYWALL TO ALLOW FOR DAMPER INSTALLATION. PROVIDE ACCESS DOOR FOR ACTUATOR SERVICE.
- ⑥ NOTE THIS IS A COMPOSITE DRAWING WHICH DOES NOT INCLUDE PROJECT PHASING. REFER TO DRAWINGS M8 & M9 FOR DUCTWORK PHASING.

2
LEVEL 4 MECHANICAL ROOM M6
HVAC SECTIONAL VIEW - COMPOSITE NEW WORK
Scale: 1:100

C