



30001402

Procurement Hub – Ottawa Office,
Station 9N089A, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

December 7, 2021

ADDENDUM NO. 1

Subject: **ITT Invitation to Tender No. 30001402**

Title: Contractor Services for Robin Hood Bay Perimeter Lighting

Location: Sugar Loaf Road, St. John's, T.-N.-L

Closing Date: **December 13, 2021 @ 2:00 PM (EST)**

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum #1** is to advise potential bidders of the following amendment, questions and answers received to date:

To Delete:

Solicitation Closes / L'invitation prend fin

At / à : 2 :00 PM

EST (Eastern Standard Time)

On / le : December 7, 2021

To Insert:

Solicitation Closes / L'invitation prend fin

At / à : 2 :00 PM

EST (Eastern Standard Time)

On / le : December 13, 2021

Q1 : We are looking for clarification on the following:

Description of Work:

Section: 2.1.5 Refers to "Gravity Base Crib" There is no detail of such item. Please clarify.



30001402

Drawing "E02 Electrical Floor Plan and Details" Detail "3/E02 Typical Pole Detail" Refers to "see Structural Drawing for Pole Base Detail" There are no structural drawings. Please clarify.

R1: Structural drawing attached. Crib detail to be used only when rock is encountered and proper depth cannot be achieved. Price per each crib to be provided in bid submittal should this extra be required.

Q2 : For the subject tender package can you provide current site photos of pole locations, trenching paths and photo of existing . Unfortunately we were unable to have anyone available for the site visit that was schedule due to prior commitments.

R2: See attached photos. To clarify, shipping containers will not be moved. Trees surrounding storage pad can be removed as required to facilitate trenching. Contractor to discuss with engineer onsite plan for tree removal.



Photo 1: Building Entrance



30001402



Photo 2: Training Shack



Photo 3: Buried 4800V (encased in concrete) see raised berm center



30001402



Photo 4: SW Corner of storage pad



Photo 5: West side of storage pad



30001402



Photo 6: West side of storage pad



Photo 7: NW side of storage pad



30001402



Photos 8: North side of storage pad

Yours truly,

Ginette Aliaga

Procurement and Contracting Officer

Procurement Hub, Materiel and Procurement Services

Fisheries and Oceans Canada

200 Kent Street, 9N089A

Ottawa, ON, K1A 0E6

Email: Ginette.AliagaGallo@dfo-mpo.gc.ca