

PART 1 - GENERAL

- | | | |
|--|----|--|
| <u>1.1 ACTION AND INFORMATIONAL SUBMITTALS</u> | .1 | Product Data:
.1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations. |
| | .2 | Quality assurance submittals: provide the following:
.1 Manufacturer's instructions: provide manufacturer's written installation instructions and special handling criteria, installation sequence and cleaning procedures. |
| | .3 | Submit shop drawings: Include point by point illumination calculations for all under canopy areas. |
| <u>1.2 DELIVERY, STORAGE AND HANDLING</u> | .1 | Deliver, store and handle materials in accordance with manufacturer's instructions. |

PART 2 - PRODUCTS

- | | | |
|-------------------------|----|---|
| <u>2.1 LIGHT SOURCE</u> | .1 | LED as described on drawings. |
| <u>2.2 FINISHES</u> | .1 | Light fixture finish and construction to meet ULC listings and CSA certifications related to intended installation. |
| <u>2.3 LUMINARIES</u> | .1 | As described on the drawing. Lighting description indicates the standard of quality, performance, appearance and style required and may vary slightly depending on the manufacturer's products. |
-

PART 3 - EXECUTION

- | | | |
|-------------------------------|----|---|
| <u>3.1 INSTALLATION</u> | .1 | Locate and install luminaries as indicated. |
| | .2 | Provide adequate support to suit ceiling system. Provide additional support hangers attached to the building structure. |
| <u>3.2 WIRING</u> | .1 | Connect luminaires to existing lighting circuits:
.1 Install flexible conduit or armoured cable for fixture drops. |
| <u>3.3 LUMINAIRE SUPPORTS</u> | .1 | Support luminaries independently of ceiling. |
| <u>3.4 CLEANING</u> | .1 | At the completion of the work, thoroughly clean all light fixtures and lens. |