

PART 1 - GENERAL

- 1.1 REFERENCES .1 Canadian Environmental Protection Act (CEPA)
.1 SOR/2008-197, Storage Tank Systems for Petroleum Products and Allied Petroleum Products Regulations.
- 1.2 ADMINISTRATIVE REQUIREMENTS .1 Pre-warranty Meeting:
.1 Convene meeting one week prior to contract completion with contractor's representative and Departmental Representative, in accordance with Section 01 31 19 - Project Meetings to:
.1 Verify Project requirements.
.2 Review manufacturer's installation instructions and warranty requirements.
.2 Departmental Representative to establish communication procedures for:
.1 Notifying construction warranty defects.
.2 Determine priorities for type of defects.
.3 Determine reasonable response time.
.3 Contact information for bonded and licensed company for warranty work action: provide name, telephone number and address of company authorized for construction warranty work action.
.4 Ensure contact is located within local service area of warranted construction, is continuously available, and is responsive to inquiries for warranty work action.
- 1.3 ACTION AND INFORMATIONAL SUBMITTALS .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
.2 Two weeks prior to Substantial Performance of the Work, submit to the Departmental Representative, two final copies of operating and maintenance manuals in English.
.3 Provide spare parts, maintenance materials and special tools of same quality and manufacture as products provided in Work.
-

1.3 ACTION AND
INFORMATIONAL
SUBMITTALS
(Cont'd)

- .4 Provide evidence, if requested, for type, source and quality of products supplied.

1.4 FORMAT

- .1 Organize data as instructional manual.
- .2 Binders: vinyl, hard covered, 3 'D' ring, loose leaf 219 x 279 mm with spine and face pockets.
- .3 When multiple binders are used correlate data into related consistent groupings.
.1 Identify contents of each binder on spine.
- .4 Cover: identify each binder with type or printed title 'Project Record Documents'; list title of project and identify subject matter of contents.
- .5 Arrange content by systems, under Section numbers and sequence of Table of Contents.
- .6 Provide tabbed fly leaf for each separate product and system, with typed description of product and major component parts of equipment.
- .7 Text: manufacturer's printed data, or typewritten data.
- .8 Drawings: provide with reinforced punched binder tab.
.1 Bind in with text; fold larger drawings to size of text pages.

1.5 CONTENTS -
PROJECT RECORD
DOCUMENTS

- .1 Table of Contents for Each Volume: provide title of project;
.1 Date of submission; names.
.2 Addresses, and telephone numbers of Departmental Representative and Contractor with name of responsible parties.
.3 Schedule of products and systems, indexed to content of volume.
- .2 For each product or system:
-

1.5 CONTENTS -
PROJECT RECORD
DOCUMENTS
(Cont'd)

- .2 (Cont'd)
 - .1 List names, addresses and telephone numbers of subcontractors and suppliers, including local source of supplies and replacement parts.
- .3 Product Data: mark each sheet to identify specific products and component parts, and data applicable to installation; delete inapplicable information.
- .4 Drawings: supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams.
- .5 Typewritten Text: as required to supplement product data.
 - .1 Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions specified in Section 01 45 00 - Quality Control.
- .6 Training: refer to Section 01 79 00 - Demonstration and Training.

1.6 AS -BUILT
DOCUMENTS AND
SAMPLES

- .1 Maintain, in addition to requirements in General Conditions, at site for Departmental Representative one record copy of:
 - .1 Contract Drawings.
 - .2 Specifications.
 - .3 Addenda.
 - .4 Change Orders and other modifications to Contract.
 - .5 Reviewed shop drawings, product data, and samples.
 - .6 Field test records.
 - .7 Inspection certificates.
 - .8 Manufacturer's certificates.
 - .2 Store record documents and samples in field office apart from documents used for construction.
 - .1 Provide files, racks, and secure storage.
 - .3 Label record documents and file in accordance with Section number listings in List of Contents of this Project Manual.
-

- 1.6 AS -BUILT DOCUMENTS AND SAMPLES
(Cont'd)
- .3 (Cont'd)
 - .1 Label each document "PROJECT RECORD" in neat, large, printed letters.
 - .4 Maintain record documents in clean, dry and legible condition.
 - .1 Do not use record documents for construction purposes.
 - .5 Keep record documents and samples available for inspection by Departmental Representative.
- 1.7 RECORDING INFORMATION ON PROJECT RECORD DOCUMENTS
DOCUMENTS
- .1 Record information on set of black line opaque drawings, and in copy of Project Manual, provided by Departmental Representative.
 - .2 Use felt tip marking pens, maintaining separate colours for each major system, for recording information.
 - .3 Record information concurrently with construction progress.
 - .1 Do not conceal Work until required information is recorded.
 - .4 Contract Drawings and shop drawings: mark each item to record actual construction, including:
 - .1 Field changes of dimension and detail.
 - .2 Changes made by change orders.
 - .3 Details not on original Contract Drawings.
 - .4 References to related shop drawings and modifications.
 - .5 Specifications: mark each item to record actual construction, including:
 - .1 Manufacturer, trade name, and catalogue number of each product actually installed, particularly optional items and substitute items.
 - .2 Changes made by Addenda and change orders.
 - .6 Other Documents: maintain manufacturer's certifications, inspection certifications, field test records, required by individual specifications sections.
-

1.7 RECORDING
INFORMATION ON
PROJECT RECORD
DOCUMENTS

(Cont'd)

- .7 Provide digital photos, if requested, for site records.

1.8 EQUIPMENT AND
SYSTEMS

- .1 For each item of equipment and each system include description of unit or system, and component parts.
- .1 Give function, normal operation characteristics and limiting conditions.
 - .2 Include performance curves, with engineering data and tests, and complete nomenclature and commercial number of replaceable parts.
- .2 Panel board circuit directories: provide electrical service characteristics, controls, and communications.
- .3 Include installed colour coded wiring diagrams.
- .4 Operating Procedures: include start-up, break-in, and routine normal operating instructions and sequences.
- .1 Include regulation, control, stopping, shut-down, and emergency instructions.
 - .2 Include summer, winter, and any special operating instructions.
- .5 Maintenance Requirements: include routine procedures and guide for trouble-shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- .6 Provide servicing and lubrication schedule, and list of lubricants required.
- .7 Include manufacturer's printed operation and maintenance instructions.
- .8 Include sequence of operation by controls manufacturer.
- .9 Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
-

- | | | |
|---------------------------------------|-----|--|
| 1.8 EQUIPMENT AND SYSTEMS
(Cont'd) | .10 | Provide installed control diagrams by controls manufacturer. |
| | .11 | Provide Contractor's co-ordination drawings, with installed colour coded piping diagrams. |
| | .12 | Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams. |
| | .13 | Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage. |
| | .14 | Include test and balancing reports as specified in Section 01 45 00 - Quality Control. |
| 1.9 MATERIALS AND FINISHES | .1 | Building products, applied materials, and finishes: include product data, with catalogue number, size, composition, and colour and texture designations.
.1 Provide information for re-ordering custom manufactured products. |
| | .2 | Instructions for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance. |
| | .3 | Moisture-protection and weather-exposed products: include manufacturer's recommendations for cleaning agents and methods, precautions against detrimental agents and methods, and recommended schedule for cleaning and maintenance. |
| | .4 | Additional requirements: as specified in individual specifications sections. |
| 1.10 MAINTENANCE MATERIALS | .1 | Spare Parts:
.1 Provide spare parts, in quantities specified in individual specification sections.
.2 Provide items of same manufacture and quality as items in Work.
.3 Deliver to site; place and store. |

- | | | |
|--|-------------|---|
| 1.10 MAINTENANCE MATERIALS
<u>(Cont'd)</u> | .1 (Cont'd) | |
| | .4 | Receive and catalogue items. |
| | .1 | Submit inventory listing to Departmental Representative. |
| | .2 | Include approved listings in Maintenance Manual. |
| | .5 | Obtain receipt for delivered products and submit prior to final payment. |
| | .2 | Special Tools: |
| | .1 | Provide special tools, in quantities specified in individual specification section. |
| | .2 | Provide items with tags identifying their associated function and equipment. |
| | .3 | Deliver to site; place and store. |
| | .4 | Receive and catalogue items. |
| | .1 | Submit inventory listing to Departmental Representative. |
| | .2 | Include approved listings in Maintenance Manual. |
| 1.11 DELIVERY, STORAGE AND HANDLING
<u></u> | .1 | Store spare parts, maintenance materials, and special tools in manner to prevent damage or deterioration. |
| | .2 | Store in original and undamaged condition with manufacturer's seal and labels intact. |
| | .3 | Store components subject to damage from weather in weatherproof enclosures. |
| | .4 | Store paints and freezable materials in a heated and ventilated room. |
| | .5 | Remove and replace damaged products at own expense and for review by Departmental Representative. |
| 1.12 WARRANTIES AND BONDS
<u></u> | .1 | Develop warranty management plan to contain information relevant to Warranties. |
| | .2 | Submit warranty management plan, 30 days before planned pre-warranty conference, to Departmental Representative approval. |
-

- 1.12 WARRANTIES AND BONDS
(Cont'd)
- .3 Warranty management plan to include required actions and documents to assure that Departmental Representative receives warranties to which it is entitled.
 - .4 Provide plan in narrative form and contain sufficient detail to make it suitable for use by future maintenance and repair personnel.
 - .5 Submit, warranty information made available during construction phase, to Departmental Representative for approval prior to each monthly pay estimate.
 - .6 Assemble approved information in binder, submit upon acceptance of work and organize binder as follows:
 - .1 Separate each warranty or bond with index tab sheets keyed to Table of Contents listing.
 - .2 List subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.
 - .3 Obtain warranties and bonds, executed in duplicate by subcontractors, suppliers, and manufacturers, within ten days after completion of applicable item of work.
 - .4 Verify that documents are in proper form, contain full information, and are notarized.
 - .5 Co-execute submittals when required.
 - .6 Retain warranties and bonds until time specified for submittal.
 - .7 Except for items put into use with Departmental Representative's permission, leave date of beginning of time of warranty until Date of Substantial Performance is determined.
 - .8 Include information contained in warranty management plan as follows:
 - .1 Roles and responsibilities of personnel associated with warranty process, including points of contact and telephone numbers within the organizations of Contractors, subcontractors, manufacturers or suppliers involved.
-

1.12 WARRANTIES AND .8
BONDS

(Cont'd)

(Cont'd)

.2 Listing and status of delivery of Certificates of Warranty for extended warranty items, to include roofs, HVAC balancing, pumps, motors, transformers, and commissioned systems such as fire protection, alarm systems, sprinkler systems, lightning protection systems.

.3 Provide list for each warranted equipment, item, feature of construction or system indicating:

.1 Name of item.

.2 Model and serial numbers.

.3 Location where installed.

.4 Name and phone numbers of manufacturers or suppliers.

.5 Names, addresses and telephone numbers of sources of spare parts.

.6 Warranties and terms of warranty: include one-year overall warranty of construction. Indicate items that have extended warranties and show separate warranty expiration dates.

.7 Cross-reference to warranty certificates as applicable.

.8 Starting point and duration of warranty period.

.9 Summary of maintenance procedures required to continue warranty in force.

.10 Cross-Reference to specific pertinent Operation and Maintenance manuals.

.11 Organization, names and phone numbers of persons to call for warranty service.

.12 Typical response time and repair time expected for various warranted equipment.

.9 Respond in timely manner to oral or written notification of required construction warranty repair work.

.10 Written verification to follow oral instructions.

.1 Failure to respond will be cause for the Departmental Representative to proceed with action against Contractor.

PART 2 - PRODUCTS

2.1 NOT USED .1 Not Used.

PART 3 - EXECUTION

3.1 NOT USED .1 Not Used.