



Date: December 17, 2021

Title: HVAC and Control Recapitalization at the High Commission of Canada in Jamaica

Solicitation: 21-186249

---

The following Questions & Answers is in link with the solicitation document mentioned above.

---

### Questions & Answers # 5

**Q32.** “Who is supposed to supply the electrical drives for the ventilation equipment?”

**A32.** The drives are provided by the control contractor, see specs section 25 30 04.

**Q33.** “Can we get the model numbers for the new Condensing units COND-03,04,05?”

**A33.** Please see addendum #4 for details.

**Q34.** “Can we get the model/serial numbers of the existing AC units to be removed?”

**A34.** *(See below)*

- **Unit #1:** SAHFC40D0R00E59D3000BDGJRITY8S - Model Number  
J98L74252 - Serial Number;
- **Unit #2:** SAHFC20D0R00E18D3000BDJRITY8S - Model Number  
J98L74253 - Serial Number;
- **Unit #3:** SAHFC30D0R00E28D3000BDJRITY8S - Model Number  
J98L74254 - Serial Number;
- **Unit #4:** RAUCC25DBR000B0000000S - Model Number  
C98K00097 - Serial Number;
- **Unit #5:** RAUCC25DBR000B0000000S - Model Number  
C98K00098 - Serial Number; and
- **Unit #6:** TTA100AD0SBD - Model Number  
N482PWSAH - Serial Number.