

SECOND FLOOR PLAN HVAC

1 / H6 | H6

SCALE: 1:50

0m 1m 2m 3m 4m 5m

0 10 20mm 40 60 80 100 120 140 160 180 200mm

NOTE:

1. PROVIDE NEW TEMPERATURE CONTROL VALVES (TCV) AT HEATERS WHERE INDICATED.
2. CONTRACTOR SHALL PATCH & PAINT WALLS WHERE EXISTING CONTROLLERS & THERMOSTATS WERE REMOVED.

PWGSC A1 (2004)

Public Works and Government Services Canada | Travaux Publics et Services gouvernementaux Canada

MCA CONSULTANTS INC
ENGINEERS · PROJECT MANAGEMENT
902.566.9223 | info@mcaconsultants.ca | www.mcaconsultants.ca

LEGEND

- EXISTING EQUIPMENT TO BE REMOVED
- EXISTING EQUIPMENT TO REMAIN
- NEW EQUIPMENT
- C — CONDENSATE PIPING
- EXISTING DIFFUSER TO REMAIN
- T — EXISTING TSTAT TO REMAIN
- T — EXISTING TSTAT TO BE REMOVED
- S — NEW PLATE SENSOR
- S AD — NEW ADJUSTABLE SENSOR
- IMD — INTELLIGENT MOTORIZED DISC DAMPER
- BD — BALANCING DAMPER
- M — NEW MOTORIZED DAMPER

PROFESSIONAL ENGINEER — The Association of Professional Engineers of Prince Edward Island — Christine E. Dowling — 1759 — 2021/11/10 Date — Province of Prince Edward Island

revisions		date
0	ISSUED FOR TENDER	Nov. 10 2021

project / projet

ARDGOWAN
HVAC CONTROLS UPGRADE
CHARLOTTETOWN,
QUEENS CO., PE

drawing / dessin

SECOND FLOOR PLAN
HVAC

designed / conçu: CED
date: NOVEMBER, 2021
drawn / dessiné: LJDJ
date: NOVEMBER, 2021
approved / approuvé: CED
date: NOVEMBER, 2021

Tender / Soumission
Andrea T Richard — Digitally signed by Andrea T Richard Date: 2021.11.25 14:20:55 -04'00'
PWGSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet: R.116036.001

drawing no. / no. du dessin: H6 of 8

E-DRM/GDD-E: 553426