



1. DISCONNECT AND REMOVE EXISTING WIRING TO THE ELECTRIC BASEBOARD HEATER WITH INTEGRAL THERMOSTAT. THE HEATERS WILL BE REMOVED AND DISPOSED OF BY THE DIVISION 15 CONTRACTOR.
2. DISCONNECT AND REMOVE THE EXISTING WIRING TO THE ELECTRIC FORCE FLOW HEATER WITH INTEGRAL THERMOSTAT. THE HEATER WILL BE REMOVED AND DISPOSED OF BY THE DIVISION 15 CONTRACTOR.



ENGINEERS - PROJECT MANAGEMENT  
902.566.9223 | info@mcaconsultants.ca  
www.mcaconsultants.ca

**RICHARDSON ASSOCIATES**  
(1993) Limited  
Engineering Consultants  
Telephone: 902.566.4044  
Facsimile: 902.566.4069  
E-mail: bauer@ra93.com  
P.O. Box 1067  
655 North River Road, Suite 1  
Charlottetown, Prince Edward Island  
Canada C1A 7M4

## LEGEND

- EXISTING EQUIPMENT TO BE REMOVED
- EXISTING EQUIPMENT TO REMAIN
- NEW EQUIPMENT
- \$2P 2 POLE TOGGLE SWITCH
- \$M HORSE POWER RATED TOGGLE SWITCH
- ELECTRICAL PANEL, SURFACE MOUNTED
- DISCONNECT SWITCH
- 4X NEMA 4X RATED EQUIPMENT
- WP WEATHERPROOF
- er EXISTING EQUIPMENT TO BE REMOVED
- e EXISTING EQUIPMENT TO REMAIN
- er EXISTING EQUIPMENT TO BE REMOVED



0	ISSUED FOR TENDER	10/11/21
revisions		date
project		projet

**ARDGOWAN  
HVAC CONTROLS UPGRADE  
CHARLOTTETOWN,  
QUEENS CO., PE**

## BASEMENT PLAN ELECTRICAL DEMOLITION

designed	RLS	conçu
date	MAY 7, 2021	
drawn	RLS	dessiné
date	MAY 7, 2021	
approved	RLS	approuvé
date	APRIL 23, 2021	
Tender		Soumission

PWSC Project Manager	Administrateur de projets TPSGC
project number	no. du projet
<b>R.116036.001</b>	
drawing no.	no. du dessin

**E1 of 7**