

BASEMENT PLAN HVAC DEMOLITION

1 | H1 | H1

SCALE: 1:50

0m 1m 2m 3m 4m 5m

NOTE:

1. ALL INTELLIGENT MOTORIZED DAMPERS (IMD) AND ASSOCIATED WIRING TO BE REMOVED.
2. ALL EXISTING BASEBOARD TEMPERATURE CONTROL VALVES (TCV) TO BE REMOVED.

Public Works and Government Services Canada | Travaux Publics et Services gouvernementaux Canada

MCA CONSULTANTS INC
ENGINEERS · PROJECT MANAGEMENT
902.566.9223 | info@mcaconsultants.ca | www.mcaconsultants.ca

LEGEND

- EXISTING EQUIPMENT TO BE REMOVED
- EXISTING EQUIPMENT TO REMAIN
- NEW EQUIPMENT
- C — CONDENSATE PIPING
- EXISTING DIFFUSER TO REMAIN
- T — EXISTING TSTAT TO REMAIN
- EXISTING TSTAT TO BE REMOVED
- S — NEW PLATE SENSOR
- SAD — NEW ADJUSTABLE SENSOR
- IMD — INTELLIGENT MOTORIZED DISC DAMPER
- BD — BALANCING DAMPER
- M — NEW MOTORIZED DAMPER

PROFESSIONAL ENGINEER — Christine E Dowling — 1759 — 2021/11/10 — PROVINCE OF PRINCE EDWARD ISLAND

0	ISSUED FOR TENDER	Nov. 10 2021
revisions		date

project / projet

ARDGOWAN
HVAC CONTROLS UPGRADE
CHARLOTTETOWN,
QUEENS CO., PE

drawing / dessin

BASEMENT PLAN
HVAC DEMOLITION

designed	CED	conçu
date	NOVEMBER, 2021	
drawn	LJDJ	dessiné
date	NOVEMBER, 2021	
approved	CED	approuvé
date	NOVEMBER, 2021	

Tender / Soumission

Andrea T Richard — Digitally signed by Andrea T Richard, Date: 2021.11.25 14:17:39 -04'00'

PWGSC Project Manager / Administrateur de projets TPSGC

project number / no. du projet: **R.116036.001**

drawing no. / no. du dessin: **H1 of 8**

PWGSC A1 (2004)

0 10 20mm 40 60 80 100 120 140 160 180 200mm

E-DRM/GDD-E: 553426 v1