



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Box/Boîte de Réception des  
Soumissions**

**1st Floor/1<sup>ère</sup> étage, Suite 1212**

**100-1045 Main Street**

**Moncton**

**New Brunswick**

**E1C 1H1**

**Bid Fax: (506) 851-6759**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Acquisitions NB/PEI (Moncton Office) – Bureau

d'acquisitions N.-B./Î.-P.-É. (Moncton)

1045 Main Street / 1045, rue Main

Moncton

New Bruns

E1C 1H1

<b>Title - Sujet</b> Wharf Reconstruction – Phase 2, Str Wharf Reconstruction – Phase 2, Structure 408, Val-Comeau, NB	
<b>Solicitation No. - N° de l'invitation</b> EC015-221158/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> EC015-221158	<b>Date</b> 2021-12-21
<b>GETS Reference No. - N° de référence de SEAG</b> PW-SPWJ-017-6082	
<b>File No. - N° de dossier</b> PWJ-1-44072 (017)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Atlantic Standard Time AST <b>on - le 2022-01-12</b> Heure Normale de l'Atlantique HNA	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Stockman (PWJ), Sonia	<b>Buyer Id - Id de l'acheteur</b> pwj017
<b>Telephone No. - N° de téléphone</b> (506) 961-7412 ( )	<b>FAX No. - N° de FAX</b> (506) 851-6759
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EC015-221158/A  
Client Ref. No. - N° de réf. du client  
No./N° VME  
R.097242.003

Amd. No. - N° de la modif.  
005  
File No. - N° du dossier  
PWJ-1-44072

Buyer ID - Id de l'acheteur  
pwj017  
CCC No./N° CCC - FMS

---

This Solicitation Amendment No. five (005) is raised to include the following addendum no. 005.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents. All other terms and conditions remain the same.

Addendum No. 005. This invitation to tender is hereby amended to:

(1) Answer the following question:

**Question #10:**

Section 26 05 31 - 2.2, The 3 attachment points for the doors. Can you specify what kind of attachment points?

**Response#10:**

See attached clarifications/revisions.

By submission of its bid, the bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount. All other terms & conditions remain unchanged.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the above address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged.

All enquiries concerning this amendment are to be forwarded to:

Name: Sonia Stockman  
Telephone No: (506) 961-7412

Our Ref: 1850

2021.12.20

**ELECTRICAL ADDENDUM #3  
WHARF RECONSTRUCTION  
STRUCTURE 408 (PHASE 2)  
VAL-COMEAU, N.B.  
PSPC PROJECT NO. R.097242.003**

---

**THE ELECTRICAL CONTRACTOR IS TO SUPPLY, INSTALL AND COMMISSION ALL LABOR AND MATERIAL TO COMPLETE THE FOLLOWING ADDITIONAL WORK FOR THE ABOVE PROJECT IN THE CONTRACTOR'S SUBMITTED TENDER PRICE:**

<b><u>ITEM</u></b>	<b><u>REFERENCE</u></b>	<b><u>DESCRIPTION</u></b>	
1.	Drawing E4	.1	Wire sizes on Single Line Diagram Detail 1 on Dwg. E4 for ES11, ES12 and ES13 are to be corrected as per notes 9, 10, 11 on Dwg. E4.
		.2	On Dwg. E4 Shroud ES10, light fixtures are corrected to L6-1 and L6-2.
		.3	On Dwg. E4 Shroud ES13, light fixtures are corrected to L7-1 and L7-2.
2.	Spec Section 26 05 31.2.2	.1	The 3-point latch system is a standard latch system used by large panel manufacturers. The system consists of all 316 grade stainless steel components with a center blade latch midway on the latch side of the door and two (2) rods with blade latches at the top and bottom of the door. The system also has a non-locking low profile handle on the outside of the door at the center latch side of the door. All mounting hardware to be 316 grade stainless steel.

RAS/br