



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions -
TPSGC**

**See herein for bid submission
instructions/**

**Voir la présente pour les
instructions sur la présentation
d'une soumission**

NA

British Columbia

NA

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Steveston Paramount Wharf 403 Recon Reconstruction du quai 403 de Steveston Paramount	
Solicitation No. - N° de l'invitation F1571-210984/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client F1571-210984	Date 2022-01-06
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-9095	
File No. - N° de dossier PWY-1-44142 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2022-01-25 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Steveston Paramount Wharf 403 – Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1571-210984/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

The Solicitation Amendment 002 is raised to issue Addendum 001.

See Addendum 001 herein.

All other terms and conditions remain unchanged.

Solicitation No. - N° de l'invitation
F1571-210984/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

BID AND ACCEPTANCE FORM (BA) – REVISED DECEMBER 7, 2021

BA01 IDENTIFICATION

Steveston Paramount Building 25 Demolition
Richmond, BC

BA02 LEGAL NAME AND ADDRESS OF BIDDER

Legal Name:					
Operating Name (if any):					
Address:					
Telephone:		Fax:		PBN:	
E-mail address:					
Contract Security Program Organisation Number (when required)					

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the **TOTAL BID AMOUNT INDICATED IN APPENDIX 1.**

BA04 BID VALIDITY PERIOD

The bid must not be withdrawn for a period of 30 days following the date of solicitation closing.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Bidder's offer by Canada, a binding Contract will be formed between Canada and the Bidder. The documents forming the Contract will be the Contract Documents identified in "Contract Documents (CD)" section.

BA06 CONSTRUCTION TIME

The Contractor must perform and complete the Work before **May 31, 2022.**

BA07 BID SECURITY

The Bidder must enclose bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services - Bid Security Requirements.

BA08 SIGNATURE

--

Name and title of person authorized to sign on behalf of Bidder (Type or print)

--

Signature

--

Date

The following changes in the tender documents are effective immediately. This Addendum will form part of the contract documents.

Questions and Answers

Q1. 1. Lengths of the Anchor Rods? They are not defined in the dwgs...maybe if Details C/012 and E/012, etc. were in the dwgs (they are "missing?") then that may possibly be the ultimate piece information we need to calculate the lengths? Anyhow, in my lowly opinion, such lengths should be defined due to the multiple different lengths that are required (an Anchor Rod schedule would be great....that goes for the Sheet pile s too...).

A1: Lengths of the anchor rods can be determined from the drawings.

Q2. Lengths of the Pipe Piles...? There's no way, as far as I can determine at least, a way to figure out the lengths.

A2: There is no pipe piles required for the work.

Q3. #18 DCP (57mm dia.) 14.5m long – 40 pcs.

Thus, there are approximately 62 anchor rods in total...the Owner supplies 40 of that 62...so, which ones (quantity and length) are to be supplied by Bidders?

A3. Bidders to supply the remaining anchor rods required for the work. Contractor is required to cut the owner supplied anchor into the lengths required, and it shall be included in the tendered price. Only cut one end and the cut ends is to be inside the fill and not on the outside.

Q4. Is there a Geotechnical report of existing soils?

A4: No.

Q5. Can you please send the PWGSC drawing of the existing wharf?

A5. Refer to appendix A

Q6. Is the site accessible anytime to view?

A6. Site is accessible Monday to Friday 8am – 4pm.

----End of Addendum 001----