

**Amendment No. 005**

**ATT008**

#	Reference	Question	Response
1	Drawing Set 01 sheet E-1.1 Drawing Set 02 sheet E-C-1.1)	<p>In regards to the electrical scope of work, are we able to get a layout of building PP64.</p> <p>I am looking for clarification as to where the switchboard is located and where the new distribution panel will be located</p>	<p>See photos provided by client for site orientation. Confirmation of site conditions and all dimensions remains responsibility of Contractor.</p> <p>Ref DRAWING E-C-1.1 SITE PLAN-ELECTRICAL LAYOUTS AND LEGEND Clarification: The design intent was that Reference Drawing Set 01 sheet E-1.1, with a 600A-347/600V-3PH-4W distribution panel DP#1 connect to spare 600A breaker in existing switchboard would have work proceed prior to work indicated in Drawing Set 02 sheet E-C-1.1 with said distribution panel DP#1 in turn providing power to the Cow Barn with a 200A breaker. Spec section updated to reflect changes and clarifications per Consultant Addendum 02R1 to Set 02 .</p>

**All other terms and conditions of the Invitation-to-Tender remain unchanged.**