



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

Title - Sujet Bay 3 Refit	
Solicitation No. - N° de l'invitation 9F023-200546/A	Amendment No. - N° modif. 015
Client Reference No. - N° de référence du client 20200546	Date 2022-01-14
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-380-80685	
File No. - N° de dossier fg380.9F023-200546	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Standard Time EST on - le 2022-01-28 Heure Normale du l'Est HNE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Turner, Jason	Buyer Id - Id de l'acheteur fg380
Telephone No. - N° de téléphone (343) 574-2818 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The Amendment No.015 is issued for the following reason:

- A. To issue Addendum No. 003

A. To issue Addendum No. 003

The following changes in the bid documents are effective immediately.
This addendum 003 will form part of the construction documents.

DRAWINGS:

1. M08 Mechanical
 - .1 Add the following note to Description of HVAC New Work
 - .1 Provide new air filters for AHU-7. AHU-7 supplied by department representative.
2. M09 Mechanical
 - .1 Add the following note to Description of HVAC New Work
 - .1 Provide new air filters for AHU-8. AHU-8 supplied by department representative.
3. E05 Electrical
 - .1 Add the scope of work as identified by the revision bubbles in the drawing E05.
4. M08 Mechanical
 - .1 Description of HVAC Demolition
 - .1 Delete note 6 as follows:

~~BAS controls contractor shall remove all controls associated with removed AHU-7 and AHU-9. Retain room temperature and humidity sensors c/w wiring for reuse. AHU-9 controls to remain.~~
5. E05 Electrical
 - .1 Description of Power & Systems Demolition
 - .1 Delete note 2 as follows:

~~Disconnect and remove control panels P1-D and UPS c/w conduit and wiring to control panel AHU5 and to AHU-8. Existing controller to remain.~~

SPECIFICATIONS:

1. Add Section 23 44 00 - HVAC Air Filtration to the specifications.

2. Section 23 37 20 - Louvres:

1. Add the following sentences to paragraph 2.1 FIXED PENTHOUSE LOUVRES – ALUMINUM

.10 Penthouse louvre shall have the following dimensions:

1. Width: 900 mm
2. Depth: 900 mm
3. Height: 900 mm

.11 Penthouse louvre shall have a total free area of 0.87 m².

3. Section 25 90 01- EMCS Site Requirements, Applications and Systems Sequences of Operation

2. Add the following sentence to paragraph 1.6 DESIGNATED CONTRACTOR

.3 Refer to contact information below for Johnson Control Canada LP representative:

1. Tim Shea, 613-316-4210, Tim.J.Shea@jci.com

3. Add the following sentence to paragraph 2.1 DESIGNATED MATERIALS

.2 BAS integration of AHU-7 & AHU-8 shall be via BACnet MS/TP or IP connection to factory installed air handling unit controllers.

4. Add the following paragraph to Part 2.

.1 2.12 END DEVICES SUPPLIED LOOSE WITH AIR HANDLING UNITS

1. The following end devices shall be supplied loose by department representative to be field installed and wired to air handling unit controller by controls contractor.

- .1 Space pressure pickup tube
- .2 Outside air temperature sensor
- .3 Carbon dioxide sensor and water sensor
- .4 Outdoor relative humidity sensor
- .5 HEPA Filter dirty filter switches
- .6 Supply and return fan static pressure sensors
- .7 Discharge air humidity sensors
- .8 Discharge air damper actuator
- .9 Heating coil control valve
- .10 Cooling coil control valve

5. Add the following sentence to paragraph 3.6 GENERAL

Solicitation No. - N° de l'invitation
9F023-200546

Amd. No. - N° de la modif.
015

Buyer ID - Id del'acheteur
FG380

Client Ref. No. - N° de réf. du client
CSA15-G8b

File No. - N° du dossier
FG-9F023-200546

CCC No./N° CCC - FMS No./N° VME

- .5 Controls contractor shall coordinate with air handling unit manufacturer representative on site for integration of air handling unit controller to BAS.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME