



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

Voir dans le document/

See herein

NA

Québec

NA

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC/PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet North Warning System Hybrid Power S North Warning System Hybrid Power System	
Solicitation No. - N° de l'invitation 23332-220150/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 23332-22-0150	Date 2022-01-17
GETS Reference No. - N° de référence de SEAG PW-\$QCL-056-18266	
File No. - N° de dossier MTA-1-44079 (056)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Standard Time EST on - le 2022-03-04 Heure Normale du l'Est HNE	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mohammed-Azizi, Samia	Buyer Id - Id de l'acheteur qcl056
Telephone No. - N° de téléphone (418) 576-9803 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

N° de l'invitation - Solicitation No.
23332-220150/A
N° de réf. du client - Client Ref. No.
23332-22-0150

N° de la modif - Amd. No.
002
File No. - N° du dossier
MTA-1-44079

Id de l'acheteur - Buyer ID
QCL056
N° CCC / CCC No./ N° VME - FMS

AMENDMENT 002

The purpose of this amendment is to modify the closing date of the solicitation and answer industry question.

AMENDMENTS:

DELETE:

Solicitation Closes at 02:00 PM EST on 2022-02-11.

INSERT:

Solicitation Close at 02:00 PM EST on March 4, 2022.

ANSWERS TO INDUSTRY QUESTIONS

Enquiries - Bid Solicitation

To ensure consistency and quality of information provided to bidders, significant enquiries received and the replies to such enquiries will be provided simultaneously to bidders to which the bid solicitation has been sent, without revealing the sources of the enquiries.

Here are the questions which we have received until now:

-
- Question 1** Will the generator sets, Battery Energy Storage System, Microgrid controller, power distribution panel be installed inside a new/existing building at the site?
- Answer 1** The battery energy storage system, microgrid controller, power distribution panel (Deliverable 5A) will be installed inside an existing building at the test sites and the final destination.
- The optional battery energy storage system (Deliverable 5B) will be installed outdoors in Vancouver, BC. It is expected that the supplier will install the battery energy storage system in a container/enclosure of its own to be included with the system. However, the controllers (Microgrid controller and Battery Management System) and any human-machine interfaces and network switches can be installed in the existing containers at the site. The contractor must provide a dedicated cabinet for these control equipment and they must be wired as per the contractor's design.
- Question 2** If no to the response in a) above will the equipment need to be installed inside a sound attenuated enclosure. If so please advise sound attenuated enclosure attenuation requirements i.e. "xx dba@ 7 metres 'and any features and specification.
- Answer 2** System is to be installed in an existing structure so no sound attenuated enclosure is required.
- Question 3** Section 4.3 states that the BESS continuous rating > 90 kW and peak rating of 180 kW. Please advise the duration of the peak rating.
- Answer 3** The system should be sized to meet a peak rating of 180 kW for 30 minutes.

N° de l'invitation - Solicitation No.
23332-220150/A
N° de réf. du client - Client Ref. No.
23332-22-0150

N° de la modif - Amd. No.
002
File No. - N° du dossier
MTA-1-44079

Id de l'acheteur - Buyer ID
QCL056
N° CCC / CCC No./ N° VME - FMS

Question 4 Can we have a list of the bid takers for the project ?

Answer 4 This information is not available and cannot be disclosed in order to preserve the integrity of the procurement process.

****ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME****