



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

Title - Sujet Bay 3 Refit	
Solicitation No. - N° de l'invitation 9F023-200546/A	Amendment No. - N° modif. 016
Client Reference No. - N° de référence du client 20200546	Date 2022-01-18
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-380-80685	
File No. - N° de dossier fg380.9F023-200546	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Standard Time EST on - le 2022-01-28 Heure Normale du l'Est HNE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Turner, Jason	Buyer Id - Id de l'acheteur fg380
Telephone No. - N° de téléphone (343) 574-2818 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The Amendment No.016 is issued for the following reason:

A. To answer Question to Bidders (Q&A's)

A. To answer Question to Bidders (Q&A's)

Question 42: From addendum #9: Question 7: For the concrete demo in the loading dock what will be the hours of work and what kind of containment is required? Answer 7: Refer to Appendix A - DFL Campus Procedure for the hours of work. Contractor to remove approximately 37m2 or 400 ft2 (thickness of approximately 100mm or 4") of the existing concrete pads in the mechanical room M-6 (including the pads for the existing AHU-8). All the dust from the work must be contained in the mechanical room and exhausted directly with mechanical ventilation to the outside and away from the building. The dust must not remain on the roof surface or other surfaces on the building during this work. Contractor to provide all the equipment, tools and materials required for the work Where is the highlighted concrete demo shown on the drawings? It doesn't seem to be shown anywhere other than in this question.

Answer 42: The concrete pad is located at the proximity of the existing AHU-8 location. Refer to Drawing M09 Detail 1, Drawing M09 description of HVAC demolition note 1, and Specification 23 05 01 Common Work Results for Mechanical section 1.18.

Question 43: After looking at the pictures in the latest addendum I noticed the 600v panel that we need to add the two 150 amp breakers is a EDB style. The largest breaker in that style is 100 amp so it is not possible to use this panel. Any information in regards to this would be greatly appreciated.

Answer 43: Refer to revised drawings as per Addendum 004.

Question 44: Question MP-1-SP 600v 200 amp panel square D. They are asking for 2 x 150-amp breakers to be fed out of this panel. Our supplier has noted it they cannot get those breakers for this panel. There may also be a load issue considering the panel is only rated for 200 amp. Please clarify.

Answers 44: Refer to revised drawings as per Addendum 004.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME