
January 17, 2022

ADDENDUM NO. 4

Project Number: R.100644.001

This Addendum shall be attached to and form an integral part of the Contract Documents. The Contents of this Addendum shall be brought to the attention of and read by all concerned. Receipt of this Addendum shall be acknowledged on the Bid Form. The following changes in the bid documents are effective immediately.

The Contract Documents issued by Taylor Hazell Architects Ltd and their consultants are hereby amended as follows:

1. Specifications- Document Set 2

1. Section 11 82 01 Dairy Equipment List
 1. Section 11 82 01 is revised and re-issued with this addendum. Omit reference to schedule for item C1.1./Cooling Equipment/Condensing Unit.

2. Structural Drawings

1. DRAWING S-C-3.0 STRUCTURAL ELEVATIONS
 1. The framing elevation for gridline 3 on drawing S-C-3.0 should be corrected to indicate column C5 at gridlines 3-F/G/H and beam B3 spanning between these columns. The column and beam notations on the Structural Framing Plan S-C-2.0 are correct. Refer to sketch SSK-01.

Attach

11 82 01 - Dairy Equipment List-r2-2022-01-17-Add-4.
SSK-01-PARTIAL-FRAMING ELEVATION-GL-3-Add-4

END OF ADDENDUM NO. 4