


TRENCHING NOTES:

1. ALL TRENCHES SHALL BE BACKFILLED WITH SELECTED BACKFILL AND TAMPED IN 300mm LAYERS. EXCEPT AT ROAD CROSSINGS WHERE THE BACKFILL SHALL BE THE SAME MATERIAL AS THE ROAD BED AND TAMPED IN 150mm LAYERS. EXCESS FILL SHALL BE PLACED ON TOP TO ALLOW FOR SETTLING.
2. THE DUCTS SHALL BE SUPPORTED BY APPROVED SPACERS. NO WIRE OR METAL TIES TO BE USED.
3. COPPER FISH WIRE MINIMUM #8 MUST BE INSTALLED IN ALL DUCTS.
4. ELECTRICAL DUCT MUST BE RIGID PVC OR APPROVED EQUIVALENT.
5. ALL DUCTS AND FITTINGS MUST BE CSA APPROVED.
6. ALL DUCTS ARE TO BE SECURELY CAPPED AT BOTH ENDS.
7. ALL FITTINGS, COUPLINGS AND ADAPTERS ARE TO BE SOLVENT WELD

TRENCH DETAIL C
SCALE: N.T.S.




TRENCHING NOTES:

1. ALL TRENCHES SHALL BE BACKFILLED WITH SELECTED BACKFILL AND TAMPED IN 300mm LAYERS. EXCEPT AT ROAD CROSSINGS WHERE THE BACKFILL SHALL BE THE SAME MATERIAL AS THE ROAD BED AND TAMPED IN 150mm LAYERS. EXCESS FILL SHALL BE PLACED ON TOP TO ALLOW FOR SETTLING.
2. THE DUCTS SHALL BE SUPPORTED BY APPROVED SPACERS. NO WIRE OR METAL TIES TO BE USED.
3. COPPER FISH WIRE MINIMUM #8 MUST BE INSTALLED IN ALL DUCTS.
4. ELECTRICAL DUCT MUST BE RIGID PVC OR APPROVED EQUIVALENT.
5. ALL DUCTS AND FITTINGS MUST BE CSA APPROVED.
6. ALL DUCTS ARE TO BE SECURELY CAPPED AT BOTH ENDS.
7. ALL FITTINGS, COUPLINGS AND ADAPTERS ARE TO BE SOLVENT WELD

TRENCH DETAIL D
SCALE: N.T.S.

PERMIT
PROVINCE OF NEWFOUNDLAND
PERMIT HOLDER
Class "A"
This Permit Allows
CROSSIE ENGINEERING LIMITED
To practice Professional Engineering
in Newfoundland and Labrador
Permit No. as issued by PEG-NL 05123
which is valid for the year 2022.

STAMP
PROFESSIONAL ENGINEER
KENNETH R.P. NEL
DEC 16/21
NEWFOUNDLAND & LABRADOR




NOTES:

1. PROVIDE LED LUMINAIRE AT LOCATION INDICATED. LUMINAIRE TO BE: LITHONIA MODEL # DMW2-L24-2000LM-PCL-MD-120-GZ1-40K-MS110NWL

WATERING STATION DETAIL
N.T.S.

TRENCHING NOTES:

1. ALL TRENCHES SHALL BE BACKFILLED WITH SELECTED BACKFILL AND TAMPED IN 300mm LAYERS. EXCEPT AT ROAD CROSSINGS WHERE THE BACKFILL SHALL BE THE SAME MATERIAL AS THE ROAD BED AND TAMPED IN 150mm LAYERS. EXCESS FILL SHALL BE PLACED ON TOP TO ALLOW FOR SETTLING.
2. THE DUCTS SHALL BE SUPPORTED BY APPROVED SPACERS. NO WIRE OR METAL TIES TO BE USED.
3. COPPER FISH WIRE MINIMUM #8 MUST BE INSTALLED IN ALL DUCTS.
4. ELECTRICAL DUCT MUST BE RIGID PVC OR APPROVED EQUIVALENT.
5. ALL DUCTS AND FITTINGS MUST BE CSA APPROVED.
6. ALL DUCTS ARE TO BE SECURELY CAPPED AT BOTH ENDS.
7. ALL FITTINGS, COUPLINGS AND ADAPTERS ARE TO BE SOLVENT WELD



TRENCH DETAIL E
SCALE: N.T.S.

| | | |
|-----------|-------------------|----------|
| 0 | ISSUED FOR TENDER | 12/16/21 |
| revisions | | date |

project
DECOMMISSIONING, DEMOLITION AND SITE RESTORATION SSB HQ SOUTHSIDE ROAD ST. JOHN'S, NL

drawing
BACKFLOW PREVENTION WATER UPGRADE ELECTRICAL DETAILS

| | | |
|-----------------------|---------------------------------|---------------|
| designed | K.N. | concep |
| date | DECEMBER 2021 | |
| drawn | R.J. | dessiné |
| date | DECEMBER 2021 | |
| approved | K.N. | approuvé |
| date | DECEMBER 2021 | |
| Tender | | Soumission |
| PM/SC Project Manager | Administrateur de projets TP/SC | |
| project number | | no. du projet |
| | R.111146.001 | |
| drawing no. | | no. du dessin |
| | E17 | |