
Decommissioning, Demolition and Site Restoration SSB HQ
Southside Road, St. John's, NL
Project No. R.111146.001

2021/12/01

Section 26 05 31 – Junction and Pull Boxes

Page 1 of 1

PART 1 **GENERAL**

1.1 **REALTED SECTIONS**

- .1 Drawings and general provisions of the contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.
- .2 Section 26 05 00 – Common Work Results – Electrical.

1.2 **SUBMITTALS**

- .1 Submit shop drawings and product data for cabinets.
- .2 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada.

PART 2 **PRODUCTS**

2.1 **JUNCTION AND PULL BOXES**

- .1 Junction and pull boxes as indicated and sized on drawings.

PART 3 **EXECUTION**

3.1 **JUNCTION AND PULL BOXES INSTALLATION**

- .1 Install junction and pull boxes in locations as indicated on drawings.
- .2 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

3.2 **IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name voltage and phase.

END OF SECTION