
Decommissioning, Demolition and Site Restoration SSB HQ
Southside Road, St. John's, NL
Project No. R.111146.001

2021/12/01

Section 26 28 23 – Disconnect Switches – Fused and Non-Fused

Page 1 of 1

PART 1 **GENERAL**

1.1 **RELATED SECTIONS**

- .1 Division 01 Sections.
- .2 Section 26 05 00 – Common Work Results - Electrical.

PART 2 **PRODUCTS**

2.1 **DISCONNECT SWITCHES**

- .1 Fusible and non-fusible, disconnect switch, size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuseholders: relocatable and suitable without adaptors, for type and size of fuse indicated.
- .5 Quick-make, quick-break action.
- .6 ON-OFF switch position indication on switch enclosure cover.
- .7 Heavy duty rated.
- .8 EEMAC 4X for exterior use and EEMAC 2 for interior use.

2.2 **EQUIPMENT IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

PART 3 **EXECUTION**

3.1 **INSTALLATION**

- .1 Install disconnect switches complete with fuses as indicated.

END OF SECTION