

Solicitation # 5000062324

Questions – Answers – Modifications 01

Questions and Answers

Q1: You are asking for a factory 4 hours load bank test to be done prior to delivery. You are also asking for another load test once the equipment has been delivered to site and installed. Are these tests to be done using the building load, or a contractor supplied load bank?

A1: The contractor as to supply the load bank for the test on site. Like a regular annual load bank test.

Q2: The price table only shows two (2) 800kW generators, are we to assume that this is two (2) groups of two (2) generators?

A2: Yes, two (2) groups of two (2) generators for a total of four (4) 800kW generators.