



Date: February 21, 2022

Title: Remediation of Compound Playground for the Embassy of Canada to China

Solicitation Number: 22-204379

The following Questions & Answers is in link with the solicitation document mentioned above.

Questions & Answers #2

Q6. “Are we to change out the rubber flooring as well?”

A6. The rubber flooring is not included in this tender package. Flooring recommendation can be part of the construction/installation drawings.

Q7. “There are similar playground equipment in European countries. Are European standards acceptable?”

A7. Only CSA Standards for equipment/installation will be considered as per the Statement of Work.

Q8. “Is there a possibility of expanding the rubberized layout slightly to ensure proper safety standards are met?”

A8. Please refer to QA#1 and Addendum 2 which states that we will not be enlarging the area – we removed an item that will allow the space to be CSA approved.
