



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address:

soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 003 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

**Parks Canada Agency
National Contracting Services**

Halifax, Nova Scotia

Title: Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site	
Solicitation No.: 5P468-21-0158/B	Date: 21 February 2022
Amendment No.: 003	
Client Reference No.: 1408	
GETS Reference No.: PW-22-00984378	

Solicitation Closes: At: 14:00 On: 02 March 2022	Time Zone: EST
---	---------------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Jaime Creaser	
Telephone No.: 902-266-8592	Fax No.: 1-855-983-1808
Email Address: Jaime.Creaser@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Solicitation No.:
5P468-21-0158/B

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
1408

Title:
Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site

Amendment 003

This amendment is raised to revise the tender document, the specifications and drawings, to provide information from the bidders' conference and to answer questions from the bidders' conference.

1. Modification to Tender Document

Under section S103

INSERT:

1. An optional site visit is scheduled for 22 February 2022 at 14:00 local time. Interested bidders are to meet at 40 Bd Perron, Pointe-à-la-Croix, QC G0C 1L0.
2. Safety Attire - It is mandatory that all persons attending the site visit have the proper personal protection equipment (safety glasses, footwear, vests and hard hats etc.). Contractor's personnel/individuals who do not have the proper safety attire may be denied access to the site.
3. Bidders are requested to communicate with the Contracting Authority before the optional site visit to confirm attendance and provide the name(s) of the person(s) who will attend. Bidders may be requested to sign an attendance sheet. Bidders who do not attend or do not send a representative will not be given an alternative appointment but they will not be precluded from submitting a bid. Any clarifications or changes to the bid solicitation resulting from the site visit will be included as an amendment to the bid solicitation.
4. This site visit is subject to the COVID-19 Vaccination Policy for Supplier Personnel. The person(s) who attend must be fully vaccinated against COVID-19 with a Health Canada-approved COVID-19 vaccine(s), or, for personnel that are unable to be vaccinated due to a certified medical contraindication, religion, or other prohibited grounds of discrimination under the Canadian Human Rights Act, subject to accommodation and mitigation measures that have been presented to and approved by Canada.

Bidders must communicate with the Contracting Authority no later than 11:00 EST on 22 February 2022 to confirm attendance and provide the name(s) of the person(s) who will attend.

Bidders must also complete and submit the Certification "APPENDIX 6" (see attached) prior to the Site Visit.

2. Revisions

See below for all revisions and additions.

3. Bidders' Conference Information

Bidders' Conference Attendees

Vendor	Representative's Name
Électricité Pichette	Carl Pichette
GMV Plâtre et peinture	Jean-François Perreault
Construction Michel Maltais	Marie-Michèle Proulx

Contact information for the attendees are available upon request and approval from the vendors.

Solicitation No.:
5P468-21-0158/B

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
1408

Title:
Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site

4. Questions and Answers

Q1. Does each sub-contractor have to submit an Indigenous Benefits Plan (IBP)?

A1. Parks Canada encourages the bidder to offer specific and agreed upon benefits for Indigenous People and Indigenous Businesses linked to the region covered by the Contract. It is the Contractor's responsibility to submit the IBP. It is not mandatory for each sub-contractor to provide Indigenous benefits or resources.

Q2. What happens if no IBP is submitted with the bid?

A2. Contractor selection will be based on the highest responsive combined rating of IBP and price. The ratio will be 20% for the IBP and 80% for the price. If no IBP is submitted, the bidder would receive a score of 0/20% but would not be excluded from the process. Only the Bidder's price would earn them points. The responsive bid with the highest combined rating of IBP and price will be recommended for contract award.

Q3. How can we get in touch with Indigenous communities?

A3. Bidders can, among others, work collaboratively with the Listuguj Indigenous community, linked to the Battle of the Restigouche National Historic Site in part because of its proximity. The following person can be contacted to assist contractors in identifying Indigenous people and businesses:

Tim Dedam, Economic Development Manager
Email: tim.dedam@listuguj.ca
Telephone: 418-788-2136

Bidders are free to use other business relations or partnerships in order to establish their own collaboration.

Q4. Would it be possible to visit the site?

A4. An optional site visit has been added to the tender, see section 1 of the amendment.

Q5. How can we plan equipment costs and delivery schedule in the current pandemic situation?

A5. It is the bidders' responsibility to evaluate the risk and include a realistic and reasonable contingency while preparing their bid, based on the known vicissitudes of the actual market. The project schedule takes into account the delivery timeframe of the generator and pumps provided by the industry. The equipment will have to be ordered as soon as the contract is awarded in order to respect the project schedule.

Solicitation No.:
5P468-21-0158/B

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
1408

Title:
Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site

APPENDIX 6 - SITE VISIT COVID-19 VACCINATION REQUIREMENT CERTIFICATION

I, _____ (*first and last name*), as the representative of

_____ (*name of business*) pursuant to
_____ (*5P468-21-0158/B*), warrant and certify that all

personnel that will attend this site visit on the business' behalf are:

- (a) fully vaccinated against COVID-19; or
- (b) for personnel that are unable to be vaccinated due to a certified medical contraindication, religion or other prohibited grounds of discrimination under the Canadian Human Rights Act, subject to accommodation and mitigation measures that have been presented to and approved by Canada.

I certify that all personnel that will attend on behalf of _____
(*name of business*) have been notified of the vaccination requirements of the Government of Canada's COVID-19 Vaccination Policy for Supplier Personnel, and that the

_____ (*name of business*) has certified to their compliance with this requirement.

I certify that the information provided is true as of the date indicated below and will continue to be true for the duration of the site visit. I understand that the certifications provided to Canada are subject to verification at all times. Canada reserves the right to request additional information to verify the certifications at all times. I also understand that Canada will declare a bid non-responsive or a contractor in default, if a certification is found to be untrue, whether made knowingly or unknowingly.

Signature: _____

Date: _____

Information you provide on this Certification Form and in accordance with the Government of Canada's COVID-19 Vaccination Policy for Supplier Personnel will be protected, used, stored and disclosed in accordance with the Privacy Act. Please note that you have a right to access and correct any information on your file, and you have a right to file a complaint with the Office of the Privacy Commissioner regarding the handling of your personal information. These rights also apply to all individuals who are deemed to be personnel for the purpose for the Contract and who require access to federal government workplaces where they may come into contact with public servants.

Solicitation No.:
5P468-21-0158/B

Amendment No.:
003

Contracting Authority:
Jaime Creaser

Client Reference No.:
1408

Title:
Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED

Stantec Consulting Ltd.

250-1260 Lebourgneuf Boulevard, Quebec City QC G2K 2G2

Tél. : (418) 626-1688

Télec. : (418) 626-5464

File : Mechanical Systems Upgrade
APC Project : 1408-4

Addendum No : ME-02

Date: February 16th, 2022

Owner : Parks Canada

Project No.: 157101777

This addendum is to be read with and constitutes part of the tender document.

This addendum is an integral part of the submission documents to which it refers, by supplementing them, modifying them or eliminating certain elements.

The following amendments are brought to the technical documents submitted during the tender period.

Details of the Addendum:**1. SPECIFICATIONS****1.1 General requirements****1.1.1 Section 01 11 00 – Summary of Work**

- .1 Article 5.3.1.1 is modified as follows: Finishing paint. **In addition to the painting work explicitly mentioned on the drawings and in the specifications, the painting contractor must also paint both sides of the new type A partition installed between rooms S04A and S04B, in the same colour as the existing walls. There is no ductwork or piping to paint in this project.**

1.1.2 Section 01 14 00 – Work Restrictions

- .1 Article 1.3.3 is modified as follows: Execute work with least possible interference or disturbance to normal use of premises. Make arrangements with Agency Representative to facilitate work as stated. **Most of the work can be done during the day, on weekdays, except some service interruptions, as mentioned in section 01 11 00.**

1.2 Mechanical

1.2.1 Section 22 13 17 – Sanitary Waste and Vent Piping – Cast Iron and Copper

.1 Articles 2.2.1 and 2.2.1.1 are added:

2.2.1 Sanitary, stormwater and ventilation pipes intended for underground installation and related fittings shall be made of Class 4000 grey cast iron, with plain or hub ends, comply to CAN/CSA-B70, and shall be coated with bituminous coating.

2.2.1.1 Acceptable products: Bibby-Ste-Croix.

2. PLANS

2.1 Mechanical

2.1.1 Plan M101 – PLUMBING – DEMOLITION & CONSTRUCTION (not issued)

.1 Demolition keynote #5 is modified as follows: **CAST IRON STORM DRAIN PIPING TO DESTROY AND SEAL WATERTIGHT BY THE PLUMBING CONTRACTOR.**

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

Stantec Consulting Ltd.

Samuel Gagné, ing.
Mechanical Engineer