



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

<b>Title - Sujet</b> HVAC Design Building 14	
<b>Solicitation No. - N° de l'invitation</b> EP076-221308/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> 20221308	<b>Date</b> 2022-02-22
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-375-80871	
<b>File No. - N° de dossier</b> fg375.EP076-221308	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Eastern Standard Time EST <b>on - le 2022-02-25</b> Heure Normale du l'Est HNE	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Rudderham, Dale	<b>Buyer Id - Id de l'acheteur</b> fg375
<b>Telephone No. - N° de téléphone</b> (343) 552-1375 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

Amendment 004 is issued for the following:

- (1) To respond to questions.

---

## 1. Questions & Answers:

Q1. Who is the BAS Contractor for this project?

A2. Honeywell

Q2. Can you please answer the following related to drawing ME3

Q2a. New refrigerant pipe size?

A2a. New refrigerant pipe sizes are determined by the supplier based on length and capacity due to differing oil flow requiements between manufacturers

Q2b. New humidity connection pipe size?

A2b. 50mm distribution pipe.

Q2c. Existing Heating Glycol pipe size?

A2c. 40mm heating glycol piping reduced down to 32mm at unit connections.

Q2d. Existing Domestic water pipe size?

A2d. 20mm domectic cold water pipe.

Q3. Are you able to provide the kA ratings for panels MDP-1, Panel Condenser and Panel D?

A3. Panel MDP-1 shall be rated 14kAIC minimum. Panel Condenser and Panel D shall be rated 10kAIC minimum.

Q4. What are the sizes on the new piping to the air handling units the drawing don't show any?

A4. 40mm glycol piping reduced down to 32mm pipe. Addendum will be issued to show reducer locations.

Q5. Is it possible to specify the model of the breakers or take some pictures for the panel MDP-1?

A5. Contractor shall reach out to the panel manufacturer to obtain circuit breaker model and specification.

Q6. Is the intention to tie in the Building Automation to the existing Honeywell BAS on site?

A6. The intention is to tie into the building automation system to provide visibility to the technicians.

Q7. Are we to use the same existing wiring or is everything being removed and new wiring needs to be installed?

A7. The contractor shall follow the drawings. The drawings identify if the conduit and wire shall be removed and new circuits are to be provided or if the existing conduit and wire shall be reused.

Q8. In the quote, you asked for a DELTA controller. The building is already controlled by equipment, mostly delta. Who is the BAS controls contractor. Metasys products from Johnson Controls and Facility Explorer are therefore disqualified. Please explain.

A8. The new controls will need to be compatible with the existing controls within the building. The maintenance contractor for the building is Honeywell.

Q9. The building is already controlled by equipment, mostly delta. Which company keeps them in order (Maintenance). Metasys products from Johnson Controls and Facility Explorer are therefore disqualified. Please explain.

A9. The maintenance controls contractor is Honeywell, and new controls will need to be compatible with their existing systems.

---

All other terms and conditions remain unchanged