


SMALL CRAFT HARBOURS



NOTES


1. ALL ELEVATIONS ARE IN METRES UNLESS OTHERWISE NOTED.
2. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED.
3. DO NOT SCALE FROM DRAWINGS.
4. CONTRACTOR MUST VERIFY ALL DIMENSIONS AND CONDITIONS ON SITE PRIOR TO PROCEEDING WITH ANY PORTION OF THIS WORK.



SYMBOL	WIRE AND CONDUIT SIZE
1	2 PARALLEL RUNS OF 4 #3/0 RW90 IN 63mm (EPOXY COATED INSIDE AND OUTSIDE) RIGID GALVANIZED STEEL CONDUIT
2	4 #3/0 RW90 + 1 #4 TW GROUND IN 53mm EMT CONDUIT
3	2 #300 MCM RW90 + 1 #4 TW GROUND IN 78mm EMT CONDUIT.
4	3 #250 MCM RW90 + 1 #4 TW GROUND IN 78mm EMT CONDUIT.
5	2 PARALLEL RUNS OF 4 #3/0 RW90 + 1 #4 TW GROUND IN 53mm EMT CONDUIT.

SINGLE LINE DIAGRAM - NEW

N.T.S.



ELECTRICAL SERVICE ENTRANCE - ELEVATION

N.T.S.

stamp

permit

revision	description	date
0	ISSUED FOR TENDER	DEC 13 2021
D	ISSUED FOR PRE-TENDER REVIEW	NOV 24 2021
C	ISSUED FOR REVIEW	AUG 24 2020
B	ISSUED FOR REVIEW	JUNE 11 2020
A	ISSUED FOR REVIEW	MAY 21 2020

revisions	project	date

WHARF RECONSTRUCTION  
HARBOUR GRACE, NL

ELECTRICAL DETAILS

designed K. NEIL concu

date DECEMBER 2021

drawn K. NEIL dessine

date DECEMBER 2021

approved approve

Tender Paul Curran soumission

DFO Project Manager

project number C2-00201 no. du projet

drawing no. E7 no. du dessin