


**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid Email: soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 003 TO A
INVITATION TO TENDER**
**RÉVISION 003 INVITATION À
SOUMISSIONNER
DEMANDE D'OFFRES À
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
Calgary, AB

Title - Sujet : Lake Minnewanka Boat Launch Replacement – Banff National Park	
Solicitation No. - N° de l'invitation : 5P468-21-0226/A	Date : February 25, 2022
Amendment No. - N° de modification : 003	
Client Reference No. - N° de référence du client : N/A	
GETS Reference No. N° de référence de SEAG : PW-22-00985597	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : March 3, 2022	Time Zone - Fuseau horaire MST
--	--

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Jen Maheu		
Telephone No. - N° de telephone : (587) 432-8458	Fax No. -N° de télécopieur : 1-855-983-1808	Email Address – Courriel : jennifer.maheu@pc.gc.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P468-21-0226/A

Amd. No. - N° de la modif. :
003

Contracting Authority - Autorité contractante :
Jen Maheu

Client Ref. No. - N° de réf. du client :

Title – Titre :
Lake Minnewanka Boat Launch Replacement – Banff National Park

Amendment 003

This amendment is raised to distribute the answers to bidder questions.

A. QUESTIONS & ANSWERS

Q6 As the schedule on this Contract is very aggressive, could you please provide the following information? Anticipated date of Award?

A6 Award is anticipated such that work can likely commence March 14th, 2022

Q7 Would Parks Canada consider the following:

- Extending the hours of work in March to 6:30 AM to 8:30 PM and in April from 6:30 AM to 8:30 PM.

- Allowing work on the Easter Weekend: Friday April 15th, Saturday April 16th, Sunday April 17th

A7 Allowable work hours: March 08:30 to 21:30. April 07:30 – 21:30. Work on Easter weekend will be permitted.

Q8 Is there a possibility that weight restriction be increased and are plans available for original Construction of Bridge? And would they be available.

A8 No, posted weight restrictions may not be increased. The Lake Minnewanka dam spillway bridge is not controlled by Parks Canada.

No, as-built drawings for the bridge cannot be made available. Posted weight restrictions shall apply.

Q9 I was wondering if Parks Canada would consider an alternative to the precast slabs with our Armorflex product? Depending on the source of your slabs, it may be a cost-effective solution.

A9 Bidders are to tender their bids based on the requirements of the Contract Documents provided. The successful bidder, upon award, may propose revisions and/or alternate designs for consideration and review.

Q10 Is the existing ramp and/or new ramp area currently exposed (not under water/ice) due to winter drainage and when does it start to fill up again?

A10 Lake Minnewanka water levels are controlled by a third-party.

Parks Canada has no control over the water levels or third-party schedule.

Based on the preliminary information provided to Parks Canada, it is anticipated that the water level will be below the toe of the ramp around the week of March 21, 2022.

It is expected that the water level will continue to lower until approximately May 15, 2022 at which time it will start to rise again.

This may be subject to change for reasons outside the control of Parks Canada including weather conditions.

All work must be completed in accordance with the Contract Documents.

Q11 Although we are to provide a schedule, what is your anticipated start and/or completion dates?

A11 It is anticipated that construction on site may start approximately March 14, 2022 following the successful completion of all pre-mobilization submittals, environmental briefing and on-site pre-construction meeting.

Once approved, work may start in all dry locations.

At construction start, the toe of the ramp may not yet be fully exposed.

Solicitation No. - N° de l'invitation :
5P468-21-0226/A

Amd. No. - N° de la modif. :
003

Contracting Authority - Autorité contractante :
Jen Maheu

Client Ref. No. - N° de réf. du client :

Title – Titre :
Lake Minnewanka Boat Launch Replacement – Banff National Park

Based on the preliminary information provided to Parks Canada, it is anticipated that the water level will be below the toe of the ramp around the week of March 21, 2022.

This may be subject to change for reasons outside the control of Parks Canada including weather conditions.

Regarding schedule and completion date, as per Contract Specifications Section 01 11 00 – 1.7.6, the Contractor shall:

- Obtain the Interim Certificate (Substantial Performance) by April 23, 2022
- Complete all the Work by April 30, 2022 (Contract Completion Date)
 - o It is noted that the operator of the boat ramp requires full occupancy and use of the full ramp area starting on May 1st, 2022 to move four boats into Lake Minnewanka.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED