



RETURN BIDS TO:

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-855-983-1808

Bid E-mail Address:

soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 004 TO AN INVITATION TO TENDER

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:

**Parks Canada Agency
National Contracting Services**

Halifax, Nova Scotia

Title: Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site	
Solicitation No.: 5P468-21-0158/B	Date: 25 February 2022
Amendment No.: 004	
Client Reference No.: 1408	
GETS Reference No.: PW-22-00984378	

Solicitation Closes: At: 14:00 On: 07 March 2022	Time Zone: EST
---	---------------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Jaime Creaser	
Telephone No.: 902-266-8592	Fax No.: 1-855-983-1808
Email Address: Jaime.Creaser@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Solicitation No.:
5P468-21-0158/B

Amendment No.:
004

Contracting Authority:
Jaime Creaser

Client Reference No.:
1408

Title:
Mechanical Systems Upgrade, Battle of the Restigouche National Historic Site

Amendment 003

This amendment is raised to revise the bid closing date and to distribute questions and answers.

1. Bid Closing Date

The closing date for solicitation 5P468-21-0158/B is extended from 02 March 2022 until 07 March 2022 at 14:00 Eastern Daylight Time (EST).

2. Questions and Answers

Q6. Is the Museum self-sufficient with their own water reserve in case of fire?

A6. The water reserve consists of two (2) tanks with a combined capacity of 25,000 gallons. However, the tanks are fed by rainwater and maintaining the proper water level in the tanks has become precarious, given the low rainfall. In addition, the present work will require the shutdown of the fire pumps for a few weeks. The municipality's fire department has the necessary equipment and partnerships to ensure the protection of the building during the work related to the water source. It will be able to have additional trucks for water supply and additional assistance in case of need from nearby fire stations. It will draw up an intervention plan for this period.

Q7. Is the structure of the building made of steel, concrete or wood? Can there be presence of wood within the structure?

A7. The existing structure is made of concrete and steel, and there is no wood in the structure. The only exceptions are the outdoor belvedere and the entrance terrace (exterior), which have a wooden structure. However, there are no interventions in those areas in this project.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED