



RETURN PROPOSALS TO:
RETOURNER LES SOUMISSIONS Á:
 Parks Canada Agency Bid Receiving Unit
 National Contracting Services

Proposal Fax: 1-855-983-1808

Proposal Email:
soumissionsami-bidsrpc@pc.gc.ca

This is the only acceptable email address for responses to the bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. The Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

REVISION 002 TO A REQUEST FOR PROPOSAL

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Issuing Office:
 Parks Canada Agency
 National Contracting Services
 Calgary, AB

Title: Whistlers Campground Registration Building Acoustic Panels – Jasper National Park	
Solicitation No.: 5P468-21-0227/A	Date: February 28, 2022
Amendment No.: 002	
Client Reference No.:	
GETS Reference No.: PW-22-00985568	

Solicitation Closes: At: 2:00 PM On: March 3, 2022	Time Zone: MDT
---	--------------------------

F.O.B.: Plant: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other: <input type="checkbox"/>	
Address Enquiries to: Rebecca Chen	
Telephone No.: 587-439-3529	Fax No.: 1-866-246-6893
Email Address: rebecca.chen@pc.gc.ca	
Destination of Goods, Services, and Construction: See Herein	

TO BE COMPLETED BY THE BIDDER

Vendor/ Firm Name:	
Address:	
Telephone No.:	Fax No.:
Name of person authorized to sign on behalf of the Vendor/ Firm (type or print):	
Signature:	Date:

Amendment 002

This amendment is raised to distribute questions and answers.

A. Questions and Answers

Q2: Looking at the proposed install on plan, the design intent cannot be met with any off the shelf acoustic panels (armstrong) all panels require 4 attachment points to properly balance the acoustic panels to avoid the panels flapping with the air movement from positive pressure in HVAC systems when a door is opened. I assume contractor to use the attachment / install on plan as a design suggestion and not as PCA demanding we only use two attachment points?

A2: As per the drawings, the contractor is to design, supply, and install a bracket for each suspension point for the suspended panels. That is four brackets per panel as per the installation recommendations for the panels. The brackets are to be designed to ensure proper installation into the roof structure from which the panels will be suspended as per manufactures recommendations. It is up to the contractor to design a bracket to meet these needs. The bracket shown in the drawings are for example only.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED